

Member of the FM Global Group

FM Approvals 1151 Boston Providence Turnpike P.O. Box 9102 Norwood, MA 02062 USA T: **781 762 4300** F: 781-762-9375 www.fmapprovals.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

SIMATIC Power Modules

NI/I/2/ABCD/T*

Model No.	Description	T-Code*	Tambient
6EP1 332-1SH71	PM1207 Power Module	T4	60 ℃

Special Conditions of Use:

Equipment Ratings:

Nonincendive for use in Class I, Division 2, Groups A, B, C & D Hazardous (Classified) Locations

FM Approved for:

Siemens AG Osterreich - SIMEA A&D PLM A1211 Vienna, Austria

^{1.} Shall be installed in compliance with the enclosure, mounting, spacing and segregation requirements of the ultimate application, including a tool removable cover.



This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

Class 3600	1998
Class 3611	2004
Class 3810	2005
ANSI/ISA 61010-1	2004

Original Project ID: 3040935 Approval Granted: April 13, 2011

Subsequent Revision Reports / Date Approval Amended

Report Number Date Report Number Date

FM Approvals LLC

J. E. Marquestrot

J. E. Marquedant Group Manager 13 April 2011 Date