



Member of the FM Global Group

FM Approvals
1151 Boston-Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781 762 9375 www.fmglobal.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

Model 6GK5103-a00 Optical Link Module

NI/1/2/ABCD/T4 Ta = 60°C

NI/1/2/IIC/T4 Ta = 60°C

a = 2CA, 3CA, 4CA, 2BC, 2CC, 3CB, 3CD, 3CC, or 4CB

Special Conditions of Use:

1. The modules shall be installed in compliance with the enclosure, mounting, spacing and segregation requirements of the ultimate application, including a tool removable cover.

Equipment Ratings:

Nonincendive for Class I, Division 2, Groups A, B, C, and D Hazardous (Classified) Locations with a T4 temperature classification.

Nonincendive for Class I, Division 2, Group IIC Hazardous(Classified) Locations with a T4 temperature classification

FM Approved for:

Siemens AG
Erlangen, Germany



Member of the FM Global Group

This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

Class 3600	1998
Class 3611	2004
Class 3810	2005


Original Project ID: 3029393

Approval Granted: *MARCH 26, 2007*

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
---------------	------	---------------	------

FM Approvals LLC


 Robert L. Martell, Jr.
 Assistant Vice President

MARCH 26, 2007
Date