



Member of the FM Global Group

FM Approvals
1151 Boston Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781-762-9375 www.fmapprovals.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

SIMATIC Power Modules

NI / I / 2 / ABCD / T*

Model No.	Description	T-Code**	Tambient
6EP1 332-1SH71	PM 1207 Power Module	T4	60 °C
6EP1 332-4BA00	PM 1507 Power Module 24Vdc/3A	T4	60 °C
6EP1 333-4BA00	PM 1507 Power Module 24Vdc/8A	T4	60 °C

Special Conditions of Use:

1. Shall be installed in compliance with the enclosure, mounting, spacing and segregation requirements of the ultimate application, including a tool removable cover.
2. The maximum ambient temperature is reduced to 40 °C when mounted vertically.

Equipment Ratings:

Nonincendive for use in Class I, Division 2, Groups A, B, C & D Hazardous (Classified) Locations

FM Approved for:

Siemens AG Osterreich
A1211 Vienna, Austria

This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

Class 3600	2011
Class 3611	2004
Class 3810	2005
ANSI/ISA 61010-1	2004


Original Project ID: 3040935

Approval Granted: April 13, 2011

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
3044240	June 26, 2012		

FM Approvals LLC



Robert L. Martell, Jr.
Assistant Vice President

June 26, 2012
Date