SIEMENS

Data sheet 6GK1503-2CB00

product type designation



PROFIBUS OLM/G11 V4.0

PROFIBUS OLM/G11 V4.0 optical Link module with 1 RS485 and 1 glass fiber-optic cable interface (2 BFOC sockets), with signaling contact and test port

transfer rate	
transfer rate / with PROFIBUS	9.6 kbit/s 12 Mbit/s
transfer rate / with PROFIBUS PA	45.45 kbit/s
interfaces	
number of electrical/optical connections / for network components or terminal equipment / maximum	2
number of electrical connections	
 for network components or terminal equipment 	1
 for measuring device 	1
 for signaling contact 	1
for power supply	1
 for redundant voltage supply 	1
type of electrical connection	
 for network components or terminal equipment 	9-pin Sub-D socket
 for measuring device 	2-pole terminal block
 for power supply and signaling contact 	5-pole terminal block
number of optical interfaces / for fiber optic cable	1
design of the optical interface / for fiber optic cable	BFOC port
optical data	
attenuation factor / of the FOC transmission link	
 for glass FOC with 50/125 μm / at 3 dB/km / maximum 	10 dB
• for glass FOC with 62.5/125 μm / at 3.5 dB/km / maximum	12 dB
propagation delay [bit]	6.5 bit
connectable optical power relative to 1 mW	
 for glass FOC with 50/125 µm / at 3 dB/km 	-16 dB
• for glass FOC with 62.5/125 μm / at 3.5 dB/km	-13 dB
optical sensitivity relating to 1 mW	
 for glass FOC with 50/125 μm / at 3 dB/km 	-28 dB
• for glass FOC with 62.5/125 μm / at 3.5 dB/km	-28 dB
wavelength	
\bullet for glass FOC with 50/125 μm / compatible with interface / at 3 dB/km	860 nm
 for glass FOC with 62.5/125 μm / compatible with interface / at 3.5 dB/km 	860 nm
wire length	
 for glass FOC with 50/125 μm / at 3 dB/km / maximum 	3 km
 for glass FOC with 62.5/125 μm / at 3.5 dB/km / 	3 km

maximum	
signal inputs/outputs	0414
operating voltage / of the signaling contacts / at DC / rated value	24 V
operational current / of the signaling contacts / at DC / maximum	0.1 A
supply voltage, current consumption, power loss	
type of voltage / of the supply voltage	DC
supply voltage / at DC / rated value	24 V
supply voltage / at DC	18.8 28.8 V
product component / fusing at power supply input	Yes
consumed current / at DC / at 24 V / maximum	0.2 A
ambient conditions	0.27
ambient temperature	000.00
during operation	0 60 °C
during storage	-40 +70 °C
during transport	-40 +70 °C
relative humidity	
 at 25 °C / without condensation / during operation / maximum 	95 %
protection class IP	IP40
design, dimensions and weights	
design	compact
width	39.5 mm
height	112 mm
depth	74.5 mm
net weight	340 g
fastening method	0 + 0 · g
35 mm top hat DIN rail mounting	Yes
wall mounting	Yes
	1 63
product functions / rodundancy	
product functions / redundancy	Voc
product function / ring redundancy	Yes
product function / ring redundancy standards, specifications, approvals	Yes
product function / ring redundancy standards, specifications, approvals standard	
product function / ring redundancy standards, specifications, approvals	Yes FM3611: Class 1, Division 2, Group A, B, C, D / T4, Class 1, Zone 2, Group IIC, T4
product function / ring redundancy standards, specifications, approvals standard	FM3611: Class 1, Division 2, Group A, B, C, D / T4, Class 1, Zone 2,
product function / ring redundancy standards, specifications, approvals standard • for FM	FM3611: Class 1, Division 2, Group A, B, C, D / T4, Class 1, Zone 2, Group IIC, T4 EN 60079-0: 2006, EN60079-15: 2005, EN60079-28: 2007, II 3 (2) G Ex
product function / ring redundancy standards, specifications, approvals standard • for FM • for hazardous zone	FM3611: Class 1, Division 2, Group A, B, C, D / T4, Class 1, Zone 2, Group IIC, T4 EN 60079-0: 2006, EN60079-15: 2005, EN60079-28: 2007, II 3 (2) G Ex nA [opis] IIC T4 KEMA 09 ATEX 0173X UL 60950-1, CSA C22.2 Nr. 60950-1 UL 1604 and UL 2279-15 (Hazardous Location), CSA C22.2 No. 213-M1987, Class 1 / Division 2 / Group A, B, C, D / T4, Class 1 / Zone 2 /
product function / ring redundancy standards, specifications, approvals standard • for FM • for hazardous zone • for safety / from CSA and UL • for hazardous zone / from CSA and UL	FM3611: Class 1, Division 2, Group A, B, C, D / T4, Class 1, Zone 2, Group IIC, T4 EN 60079-0: 2006, EN60079-15: 2005, EN60079-28: 2007, II 3 (2) G Ex nA [opis] IIC T4 KEMA 09 ATEX 0173X UL 60950-1, CSA C22.2 Nr. 60950-1 UL 1604 and UL 2279-15 (Hazardous Location), CSA C22.2 No. 213-M1987, Class 1 / Division 2 / Group A, B, C, D / T4, Class 1 / Zone 2 / Group IIC / T4
product function / ring redundancy standards, specifications, approvals standard • for FM • for hazardous zone • for safety / from CSA and UL • for hazardous zone / from CSA and UL	FM3611: Class 1, Division 2, Group A, B, C, D / T4, Class 1, Zone 2, Group IIC, T4 EN 60079-0: 2006, EN60079-15: 2005, EN60079-28: 2007, II 3 (2) G Ex nA [opis] IIC T4 KEMA 09 ATEX 0173X UL 60950-1, CSA C22.2 Nr. 60950-1 UL 1604 and UL 2279-15 (Hazardous Location), CSA C22.2 No. 213-M1987, Class 1 / Division 2 / Group A, B, C, D / T4, Class 1 / Zone 2 / Group IIC / T4 EN 61000-6-4 (Class A)
product function / ring redundancy standards, specifications, approvals standard • for FM • for hazardous zone • for safety / from CSA and UL • for hazardous zone / from CSA and UL • for emitted interference • for interference immunity	FM3611: Class 1, Division 2, Group A, B, C, D / T4, Class 1, Zone 2, Group IIC, T4 EN 60079-0: 2006, EN60079-15: 2005, EN60079-28: 2007, II 3 (2) G Ex nA [opis] IIC T4 KEMA 09 ATEX 0173X UL 60950-1, CSA C22.2 Nr. 60950-1 UL 1604 and UL 2279-15 (Hazardous Location), CSA C22.2 No. 213-M1987, Class 1 / Division 2 / Group A, B, C, D / T4, Class 1 / Zone 2 / Group IIC / T4 EN 61000-6-4 (Class A) EN 61000-6-2
product function / ring redundancy standards, specifications, approvals standard • for FM • for hazardous zone • for safety / from CSA and UL • for hazardous zone / from CSA and UL • for emitted interference • for interference immunity certificate of suitability	FM3611: Class 1, Division 2, Group A, B, C, D / T4, Class 1, Zone 2, Group IIC, T4 EN 60079-0: 2006, EN60079-15: 2005, EN60079-28: 2007, II 3 (2) G Ex nA [opis] IIC T4 KEMA 09 ATEX 0173X UL 60950-1, CSA C22.2 Nr. 60950-1 UL 1604 and UL 2279-15 (Hazardous Location), CSA C22.2 No. 213-M1987, Class 1 / Division 2 / Group A, B, C, D / T4, Class 1 / Zone 2 / Group IIC / T4 EN 61000-6-4 (Class A) EN 61000-6-2 EN 61000-6-2, EN 61000-6-4
product function / ring redundancy standards, specifications, approvals standard • for FM • for hazardous zone • for safety / from CSA and UL • for hazardous zone / from CSA and UL • for emitted interference • for interference immunity certificate of suitability • CE marking	FM3611: Class 1, Division 2, Group A, B, C, D / T4, Class 1, Zone 2, Group IIC, T4 EN 60079-0: 2006, EN60079-15: 2005, EN60079-28: 2007, II 3 (2) G Ex nA [opis] IIC T4 KEMA 09 ATEX 0173X UL 60950-1, CSA C22.2 Nr. 60950-1 UL 1604 and UL 2279-15 (Hazardous Location), CSA C22.2 No. 213-M1987, Class 1 / Division 2 / Group A, B, C, D / T4, Class 1 / Zone 2 / Group IIC / T4 EN 61000-6-4 (Class A) EN 61000-6-2 EN 61000-6-2, EN 61000-6-4 Yes
product function / ring redundancy standards, specifications, approvals standard • for FM • for hazardous zone • for safety / from CSA and UL • for hazardous zone / from CSA and UL • for emitted interference • for interference immunity certificate of suitability • CE marking • C-Tick	FM3611: Class 1, Division 2, Group A, B, C, D / T4, Class 1, Zone 2, Group IIC, T4 EN 60079-0: 2006, EN60079-15: 2005, EN60079-28: 2007, II 3 (2) G Ex nA [opis] IIC T4 KEMA 09 ATEX 0173X UL 60950-1, CSA C22.2 Nr. 60950-1 UL 1604 and UL 2279-15 (Hazardous Location), CSA C22.2 No. 213-M1987, Class 1 / Division 2 / Group A, B, C, D / T4, Class 1 / Zone 2 / Group IIC / T4 EN 61000-6-4 (Class A) EN 61000-6-2 EN 61000-6-2, EN 61000-6-4 Yes Yes
product function / ring redundancy standards, specifications, approvals standard • for FM • for hazardous zone • for safety / from CSA and UL • for hazardous zone / from CSA and UL • for emitted interference • for interference immunity certificate of suitability • CE marking • C-Tick • CCC / for hazardous zone according to GB standard	FM3611: Class 1, Division 2, Group A, B, C, D / T4, Class 1, Zone 2, Group IIC, T4 EN 60079-0: 2006, EN60079-15: 2005, EN60079-28: 2007, II 3 (2) G Ex nA [opis] IIC T4 KEMA 09 ATEX 0173X UL 60950-1, CSA C22.2 Nr. 60950-1 UL 1604 and UL 2279-15 (Hazardous Location), CSA C22.2 No. 213-M1987, Class 1 / Division 2 / Group A, B, C, D / T4, Class 1 / Zone 2 / Group IIC / T4 EN 61000-6-4 (Class A) EN 61000-6-2 EN 61000-6-2, EN 61000-6-4 Yes
product function / ring redundancy standards, specifications, approvals standard	FM3611: Class 1, Division 2, Group A, B, C, D / T4, Class 1, Zone 2, Group IIC, T4 EN 60079-0: 2006, EN60079-15: 2005, EN60079-28: 2007, II 3 (2) G Ex nA [opis] IIC T4 KEMA 09 ATEX 0173X UL 60950-1, CSA C22.2 Nr. 60950-1 UL 1604 and UL 2279-15 (Hazardous Location), CSA C22.2 No. 213-M1987, Class 1 / Division 2 / Group A, B, C, D / T4, Class 1 / Zone 2 / Group IIC / T4 EN 61000-6-4 (Class A) EN 61000-6-2 EN 61000-6-2, EN 61000-6-4 Yes Yes
product function / ring redundancy standards, specifications, approvals standard • for FM • for hazardous zone • for safety / from CSA and UL • for hazardous zone / from CSA and UL • for emitted interference • for interference immunity certificate of suitability • CE marking • C-Tick • CCC / for hazardous zone according to GB standard	FM3611: Class 1, Division 2, Group A, B, C, D / T4, Class 1, Zone 2, Group IIC, T4 EN 60079-0: 2006, EN60079-15: 2005, EN60079-28: 2007, II 3 (2) G Ex nA [opis] IIC T4 KEMA 09 ATEX 0173X UL 60950-1, CSA C22.2 Nr. 60950-1 UL 1604 and UL 2279-15 (Hazardous Location), CSA C22.2 No. 213-M1987, Class 1 / Division 2 / Group A, B, C, D / T4, Class 1 / Zone 2 / Group IIC / T4 EN 61000-6-4 (Class A) EN 61000-6-2 EN 61000-6-2, EN 61000-6-4 Yes Yes
product function / ring redundancy standards, specifications, approvals standard	FM3611: Class 1, Division 2, Group A, B, C, D / T4, Class 1, Zone 2, Group IIC, T4 EN 60079-0: 2006, EN60079-15: 2005, EN60079-28: 2007, II 3 (2) G Ex nA [opis] IIC T4 KEMA 09 ATEX 0173X UL 60950-1, CSA C22.2 Nr. 60950-1 UL 1604 and UL 2279-15 (Hazardous Location), CSA C22.2 No. 213-M1987, Class 1 / Division 2 / Group A, B, C, D / T4, Class 1 / Zone 2 / Group IIC / T4 EN 61000-6-4 (Class A) EN 61000-6-2 EN 61000-6-2, EN 61000-6-4 Yes Yes
product function / ring redundancy standards, specifications, approvals standard • for FM • for hazardous zone • for safety / from CSA and UL • for hazardous zone / from CSA and UL • for emitted interference • for interference immunity certificate of suitability • CE marking • C-Tick • CCC / for hazardous zone according to GB standard Marine classification association • American Bureau of Shipping Europe Ltd. (ABS)	FM3611: Class 1, Division 2, Group A, B, C, D / T4, Class 1, Zone 2, Group IIC, T4 EN 60079-0: 2006, EN60079-15: 2005, EN60079-28: 2007, II 3 (2) G Ex nA [opis] IIC T4 KEMA 09 ATEX 0173X UL 60950-1, CSA C22.2 Nr. 60950-1 UL 1604 and UL 2279-15 (Hazardous Location), CSA C22.2 No. 213-M1987, Class 1 / Division 2 / Group A, B, C, D / T4, Class 1 / Zone 2 / Group IIC / T4 EN 61000-6-4 (Class A) EN 61000-6-2 EN 61000-6-2, EN 61000-6-4 Yes Yes
product function / ring redundancy standards, specifications, approvals standard • for FM • for hazardous zone • for safety / from CSA and UL • for hazardous zone / from CSA and UL • for emitted interference • for interference immunity certificate of suitability • CE marking • C-Tick • CCC / for hazardous zone according to GB standard Marine classification association • American Bureau of Shipping Europe Ltd. (ABS) • French marine classification society (BV)	FM3611: Class 1, Division 2, Group A, B, C, D / T4, Class 1, Zone 2, Group IIC, T4 EN 60079-0: 2006, EN60079-15: 2005, EN60079-28: 2007, II 3 (2) G Ex nA [opis] IIC T4 KEMA 09 ATEX 0173X UL 60950-1, CSA C22.2 Nr. 60950-1 UL 1604 and UL 2279-15 (Hazardous Location), CSA C22.2 No. 213-M1987, Class 1 / Division 2 / Group A, B, C, D / T4, Class 1 / Zone 2 / Group IIC / T4 EN 61000-6-4 (Class A) EN 61000-6-2 EN 61000-6-2, EN 61000-6-4 Yes Yes Yes
product function / ring redundancy standards, specifications, approvals standard • for FM • for hazardous zone • for safety / from CSA and UL • for hazardous zone / from CSA and UL • for emitted interference • for interference immunity certificate of suitability • CE marking • C-Tick • CCC / for hazardous zone according to GB standard Marine classification association • American Bureau of Shipping Europe Ltd. (ABS) • French marine classification society (BV) • Det Norske Veritas (DNV)	FM3611: Class 1, Division 2, Group A, B, C, D / T4, Class 1, Zone 2, Group IIC, T4 EN 60079-0: 2006, EN60079-15: 2005, EN60079-28: 2007, II 3 (2) G Ex nA [opis] IIC T4 KEMA 09 ATEX 0173X UL 60950-1, CSA C22.2 Nr. 60950-1 UL 1604 and UL 2279-15 (Hazardous Location), CSA C22.2 No. 213-M1987, Class 1 / Division 2 / Group A, B, C, D / T4, Class 1 / Zone 2 / Group IIC / T4 EN 61000-6-4 (Class A) EN 61000-6-2 EN 61000-6-2, EN 61000-6-4 Yes Yes Yes Yes Yes
product function / ring redundancy standard, specifications, approvals standard • for FM • for hazardous zone • for safety / from CSA and UL • for hazardous zone / from CSA and UL • for emitted interference • for interference immunity certificate of suitability • CE marking • C-Tick • CCC / for hazardous zone according to GB standard Marine classification association • American Bureau of Shipping Europe Ltd. (ABS) • French marine classification society (BV) • Det Norske Veritas (DNV) • Germanische Lloyd (GL)	FM3611: Class 1, Division 2, Group A, B, C, D / T4, Class 1, Zone 2, Group IIC, T4 EN 60079-0: 2006, EN60079-15: 2005, EN60079-28: 2007, II 3 (2) G Ex nA [opis] IIC T4 KEMA 09 ATEX 0173X UL 60950-1, CSA C22.2 Nr. 60950-1 UL 1604 and UL 2279-15 (Hazardous Location), CSA C22.2 No. 213-M1987, Class 1 / Division 2 / Group A, B, C, D / T4, Class 1 / Zone 2 / Group IIC / T4 EN 61000-6-4 (Class A) EN 61000-6-2 EN 61000-6-2, EN 61000-6-4 Yes Yes Yes Yes Yes
product function / ring redundancy standard, specifications, approvals standard • for FM • for hazardous zone • for safety / from CSA and UL • for hazardous zone / from CSA and UL • for emitted interference • for interference immunity certificate of suitability • CE marking • C-Tick • CCC / for hazardous zone according to GB standard Marine classification association • American Bureau of Shipping Europe Ltd. (ABS) • French marine classification society (BV) • Det Norske Veritas (DNV) • Germanische Lloyd (GL) • Lloyds Register of Shipping (LRS)	FM3611: Class 1, Division 2, Group A, B, C, D / T4, Class 1, Zone 2, Group IIC, T4 EN 60079-0: 2006, EN60079-15: 2005, EN60079-28: 2007, II 3 (2) G Ex nA [opis] IIC T4 KEMA 09 ATEX 0173X UL 60950-1, CSA C22.2 Nr. 60950-1 UL 1604 and UL 2279-15 (Hazardous Location), CSA C22.2 No. 213-M1987, Class 1 / Division 2 / Group A, B, C, D / T4, Class 1 / Zone 2 / Group IIC / T4 EN 61000-6-4 (Class A) EN 61000-6-2 EN 61000-6-2, EN 61000-6-4 Yes Yes Yes Yes Yes Yes Yes
product function / ring redundancy standard, specifications, approvals standard • for FM • for hazardous zone • for safety / from CSA and UL • for hazardous zone / from CSA and UL • for emitted interference • for interference immunity certificate of suitability • CE marking • C-Tick • CCC / for hazardous zone according to GB standard Marine classification association • American Bureau of Shipping Europe Ltd. (ABS) • French marine classification society (BV) • Det Norske Veritas (DNV) • Germanische Lloyd (GL) • Lloyds Register of Shipping (LRS) • Nippon Kaiji Kyokai (NK)	FM3611: Class 1, Division 2, Group A, B, C, D / T4, Class 1, Zone 2, Group IIC, T4 EN 60079-0: 2006, EN60079-15: 2005, EN60079-28: 2007, II 3 (2) G Ex nA [opis] IIC T4 KEMA 09 ATEX 0173X UL 60950-1, CSA C22.2 Nr. 60950-1 UL 1604 and UL 2279-15 (Hazardous Location), CSA C22.2 No. 213-M1987, Class 1 / Division 2 / Group A, B, C, D / T4, Class 1 / Zone 2 / Group IIC / T4 EN 61000-6-4 (Class A) EN 61000-6-2 EN 61000-6-2, EN 61000-6-4 Yes Yes Yes Yes Yes Yes Yes
product function / ring redundancy standard, specifications, approvals standard • for FM • for hazardous zone • for safety / from CSA and UL • for hazardous zone / from CSA and UL • for emitted interference • for interference immunity certificate of suitability • CE marking • C-Tick • CCC / for hazardous zone according to GB standard Marine classification association • American Bureau of Shipping Europe Ltd. (ABS) • French marine classification society (BV) • Det Norske Veritas (DNV) • Germanische Lloyd (GL) • Lloyds Register of Shipping (LRS) • Nippon Kaiji Kyokai (NK) further information / internet-Links	FM3611: Class 1, Division 2, Group A, B, C, D / T4, Class 1, Zone 2, Group IIC, T4 EN 60079-0: 2006, EN60079-15: 2005, EN60079-28: 2007, II 3 (2) G Ex nA [opis] IIC T4 KEMA 09 ATEX 0173X UL 60950-1, CSA C22.2 Nr. 60950-1 UL 1604 and UL 2279-15 (Hazardous Location), CSA C22.2 No. 213-M1987, Class 1 / Division 2 / Group A, B, C, D / T4, Class 1 / Zone 2 / Group IIC / T4 EN 61000-6-4 (Class A) EN 61000-6-2 EN 61000-6-2, EN 61000-6-4 Yes Yes Yes Yes Yes Yes Yes Yes Yes
product function / ring redundancy standards, specifications, approvals standard • for FM • for hazardous zone • for safety / from CSA and UL • for hazardous zone / from CSA and UL • for emitted interference • for interference immunity certificate of suitability • CE marking • C-Tick • CCC / for hazardous zone according to GB standard Marine classification association • American Bureau of Shipping Europe Ltd. (ABS) • French marine classification society (BV) • Det Norske Veritas (DNV) • Germanische Lloyd (GL) • Lloyds Register of Shipping (LRS) • Nippon Kaiji Kyokai (NK) further information / internet-Links Internet-Link • to website: Industrial communication	FM3611: Class 1, Division 2, Group A, B, C, D / T4, Class 1, Zone 2, Group IIC, T4 EN 60079-0: 2006, EN60079-15: 2005, EN60079-28: 2007, II 3 (2) G EX nA [opis] IIC T4 KEMA 09 ATEX 0173X UL 60950-1, CSA C22.2 Nr. 60950-1 UL 1604 and UL 2279-15 (Hazardous Location), CSA C22.2 No. 213-M1987, Class 1 / Division 2 / Group A, B, C, D / T4, Class 1 / Zone 2 / Group IIC / T4 EN 61000-6-4 (Class A) EN 61000-6-2 EN 61000-6-2, EN 61000-6-4 Yes
product function / ring redundancy standards, specifications, approvals standard	FM3611: Class 1, Division 2, Group A, B, C, D / T4, Class 1, Zone 2, Group IIC, T4 EN 60079-0: 2006, EN60079-15: 2005, EN60079-28: 2007, II 3 (2) G Ex nA [opis] IIC T4 KEMA 09 ATEX 0173X UL 60950-1, CSA C22.2 Nr. 60950-1 UL 1604 and UL 2279-15 (Hazardous Location), CSA C22.2 No. 213-M1987, Class 1 / Division 2 / Group A, B, C, D / T4, Class 1 / Zone 2 / Group IIC / T4 EN 61000-6-4 (Class A) EN 61000-6-2 EN 61000-6-2, EN 61000-6-4 Yes
product function / ring redundancy standards, specifications, approvals standard • for FM • for hazardous zone • for safety / from CSA and UL • for hazardous zone / from CSA and UL • for emitted interference • for interference immunity certificate of suitability • CE marking • C-Tick • CCC / for hazardous zone according to GB standard Marine classification association • American Bureau of Shipping Europe Ltd. (ABS) • French marine classification society (BV) • Det Norske Veritas (DNV) • Germanische Lloyd (GL) • Lloyds Register of Shipping (LRS) • Nippon Kaiji Kyokai (NK) further information / internet-Links Internet-Link • to website: Industrial communication	FM3611: Class 1, Division 2, Group A, B, C, D / T4, Class 1, Zone 2, Group IIC, T4 EN 60079-0: 2006, EN60079-15: 2005, EN60079-28: 2007, II 3 (2) G Ex nA [opis] IIC T4 KEMA 09 ATEX 0173X UL 60950-1, CSA C22.2 Nr. 60950-1 UL 1604 and UL 2279-15 (Hazardous Location), CSA C22.2 No. 213-M1987, Class 1 / Division 2 / Group A, B, C, D / T4, Class 1 / Zone 2 / Group IIC / T4 EN 61000-6-4 (Class A) EN 61000-6-2 EN 61000-6-2, EN 61000-6-4 Yes

to website: CAx-Download-Managerto website: Industry Online Support

http://www.siemens.com/cax https://support.industry.siemens.com

security information

security information

Siemens provides products and solutions with industrial security functions that support the secure operation of plants, solutions, machines, equipment and/or networks. They are important components in a holistic industrial security concept. With this in mind, Siemens' products and solutions undergo continuous development. Siemens recommends strongly that you regularly check for product updates. For the secure operation of Siemens products and solutions, it is necessary to take suitable preventive action(e.g. cell protection concept) and integrate each component into a holistic, state-of-the-art industrial security concept. Third-party products that may be in use should also be considered. For more information about industrial security, visit http://www.siemens.com/industrialsecurity. To stay informed about product updates as they occur, sign up for a product-specific newsletter. For more information, visit http://support.automation.siemens.com.

last modified:

6/30/2021