SIEMENS

Data sheet 6EP1332-1SH71



SIMATIC PM1207/1AC/24VDC/2.5A

SIMATIC S7-1200 Power Module PM1207 Stabilized power supply input: 120/230 V AC, output: DC 24 V/2,5 A

Input	
Input	1-phase AC
Note	Automatic range selection
supply voltage	
1 at AC rated value	120 V
• 2 at AC rated value	230 V
input voltage	
• 1 at AC	85 132 V
• 2 at AC	176 264 V
Wide-range input	No
Overvoltage resistance	2.3 × Vin rated, 1.3 ms
Mains buffering	at Vin = 93/187 V
Mains buffering at lout rated, min.	20 ms; at Vin = 93/187 V
Rated line frequency 1	50 Hz
Rated line frequency 2	60 Hz
Rated line range	47 63 Hz
input current	
at rated input voltage 120 V	1.2 A
at rated input voltage 230 V	0.67 A
Switch-on current limiting (+25 °C), max.	13 A
duration of inrush current limiting at 25 °C	
• maximum	3 ms
I²t, max.	0.5 A ² ·s
Built-in incoming fuse	T 3,15 A/250 V (not accessible)
Protection in the mains power input (IEC 898)	Recommended miniature circuit breaker: 16 A characteristic B or 10 A characteristic C
Output	
Output	Controlled, isolated DC voltage
Rated voltage Vout DC	24 V
output voltage at output 1 at DC rated value	24 V
Total tolerance, static ±	3 %
Static mains compensation, approx.	0.1 %
Static load balancing, approx.	0.2 %
Residual ripple peak-peak, max.	150 mV
Spikes peak-peak, max. (bandwidth: 20 MHz)	240 mV
product function output voltage adjustable	No
Output voltage setting	-
Status display	Green LED for 24 V OK
On/off behavior	No overshoot of Vout (soft start)

Startup delay, max.	6 s; 2 s at 230 V, 6 s at 120 V
Voltage rise, typ.	10 ms
Rated current value lout rated	2.5 A
Current range	0 2.5 A
supplied active power typical	60 W
short-term overload current	00 W
	6 A
on short-circuiting during the start-up typical of chart circuit during apparation typical	6 A
at short-circuit during operation typical	0 A
duration of overloading capability for excess current	400
on short-circuiting during the start-up	100 ms
at short-circuit during operation	100 ms
Parallel switching for enhanced performance	Yes
Numbers of parallel switchable units for enhanced performance	2
Efficiency	
Efficiency at Vout rated, lout rated, approx.	83 %
Power loss at Vout rated, lout rated, approx.	12 W
Closed-loop control	
Dynamic mains compensation (Vin rated ±15 %), max.	0.3 %
Dynamic load smoothing (lout: 50/100/50 %), Uout ± typ.	3 %
Load step setting time 50 to 100%, typ.	5 ms
Load step setting time 100 to 50%, typ.	5 ms
setting time maximum	5 ms
Protection and monitoring	
Output overvoltage protection	< 33 V
Current limitation, typ.	2.65 A
property of the output short-circuit proof	Yes
Short-circuit protection	Constant current characteristic
enduring short circuit current RMS value	Constant current orial acteristic
• typical	2.7 A
Overload/short-circuit indicator	-
Safety	
Primary/secondary isolation	Yes
galvanic isolation	Safety extra-low output voltage Uout acc. to EN 60950-1 and EN 50178
galvariic isolation	Safety extra-low output voltage bout acc. to Elv 60950-1 and Elv 50176
Drataation class	Class I
Protection class	Class I
leakage current	
leakage current • maximum	3.5 mA
leakage current • maximum Degree of protection (EN 60529)	
leakage current • maximum Degree of protection (EN 60529) Approvals	3.5 mA IP20
leakage current • maximum Degree of protection (EN 60529) Approvals CE mark	3.5 mA IP20 Yes
leakage current	3.5 mA IP20 Yes CULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus-Recognized (UL 60950-1, CSA C22.2 No. 60950-1) File E151273
leakage current ● maximum Degree of protection (EN 60529) Approvals CE mark UL/cUL (CSA) approval certificate of suitability ATEX	3.5 mA IP20 Yes CULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus-Recognized (UL 60950-1, CSA C22.2 No. 60950-1) File E151273 Yes; ATEX (EX) II 3G Ex nA nC IIC T4 Gc
leakage current	3.5 mA IP20 Yes CULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus-Recognized (UL 60950-1, CSA C22.2 No. 60950-1) File E151273
leakage current ● maximum Degree of protection (EN 60529) Approvals CE mark UL/cUL (CSA) approval certificate of suitability ATEX	3.5 mA IP20 Yes CULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus-Recognized (UL 60950-1, CSA C22.2 No. 60950-1) File E151273 Yes; ATEX (EX) II 3G Ex nA nC IIC T4 Gc IECEX Ex nA nC IIC T4 Gc; ATEX (EX) II 3G Ex nA nC IIC T4 Gc; cULus (ISA 12.12.01, CSA C22.2 No.213) Class I, Div. 2, Group ABCD,
leakage current ● maximum Degree of protection (EN 60529) Approvals CE mark UL/cUL (CSA) approval certificate of suitability ATEX Explosion protection	3.5 mA IP20 Yes CULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus-Recognized (UL 60950-1, CSA C22.2 No. 60950-1) File E151273 Yes; ATEX (EX) II 3G Ex nA nC IIC T4 Gc IECEX Ex nA nC IIC T4 Gc; ATEX (EX) II 3G Ex nA nC IIC T4 Gc; cULus (ISA 12.12.01, CSA C22.2 No.213) Class I, Div. 2, Group ABCD, T4, File E330455
leakage current	3.5 mA IP20 Yes CULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus-Recognized (UL 60950-1, CSA C22.2 No. 60950-1) File E151273 Yes; ATEX (EX) II 3G Ex nA nC IIC T4 Gc IECEx Ex nA nC IIC T4 Gc; ATEX (EX) II 3G Ex nA nC IIC T4 Gc; cULus (ISA 12.12.01, CSA C22.2 No.213) Class I, Div. 2, Group ABCD, T4, File E330455 Yes; IECEx Ex nA nC IIC T4 Gc
leakage current	3.5 mA IP20 Yes CULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus-Recognized (UL 60950-1, CSA C22.2 No. 60950-1) File E151273 Yes; ATEX (EX) II 3G Ex nA nC IIC T4 Gc IECEX Ex nA nC IIC T4 Gc; ATEX (EX) II 3G Ex nA nC IIC T4 Gc; cULus (ISA 12.12.01, CSA C22.2 No.213) Class I, Div. 2, Group ABCD, T4, File E330455 Yes; IECEX Ex nA nC IIC T4 Gc No
leakage current	3.5 mA IP20 Yes CULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus-Recognized (UL 60950-1, CSA C22.2 No. 60950-1) File E151273 Yes; ATEX (EX) II 3G Ex nA nC IIC T4 Gc IECEX Ex nA nC IIC T4 Gc; ATEX (EX) II 3G Ex nA nC IIC T4 Gc; cULus (ISA 12.12.01, CSA C22.2 No.213) Class I, Div. 2, Group ABCD, T4, File E330455 Yes; IECEX Ex nA nC IIC T4 Gc No Class I, Div. 2, Group ABCD, T4
leakage current	3.5 mA IP20 Yes CULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus-Recognized (UL 60950-1, CSA C22.2 No. 60950-1) File E151273 Yes; ATEX (EX) II 3G Ex nA nC IIC T4 Gc IECEX Ex nA nC IIC T4 Gc; ATEX (EX) II 3G Ex nA nC IIC T4 Gc; cULus (ISA 12.12.01, CSA C22.2 No.213) Class I, Div. 2, Group ABCD, T4, File E330455 Yes; IECEX Ex nA nC IIC T4 Gc No Class I, Div. 2, Group ABCD, T4 Yes
leakage current	3.5 mA IP20 Yes CULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus-Recognized (UL 60950-1, CSA C22.2 No. 60950-1) File E151273 Yes; ATEX (EX) II 3G Ex nA nC IIC T4 Gc IECEX Ex nA nC IIC T4 Gc; ATEX (EX) II 3G Ex nA nC IIC T4 Gc; cULus (ISA 12.12.01, CSA C22.2 No.213) Class I, Div. 2, Group ABCD, T4, File E330455 Yes; IECEX Ex nA nC IIC T4 Gc No Class I, Div. 2, Group ABCD, T4 Yes Yes
leakage current	3.5 mA IP20 Yes CULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus-Recognized (UL 60950-1, CSA C22.2 No. 60950-1) File E151273 Yes; ATEX (EX) II 3G Ex nA nC IIC T4 Gc IECEX Ex nA nC IIC T4 Gc; ATEX (EX) II 3G Ex nA nC IIC T4 Gc; cULus (ISA 12.12.01, CSA C22.2 No.213) Class I, Div. 2, Group ABCD, T4, File E330455 Yes; IECEX Ex nA nC IIC T4 Gc No Class I, Div. 2, Group ABCD, T4 Yes Yes ABS, BV, DNV GL, LRS, NK
leakage current	3.5 mA IP20 Yes CULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus-Recognized (UL 60950-1, CSA C22.2 No. 60950-1) File E151273 Yes; ATEX (EX) II 3G Ex nA nC IIC T4 Gc IECEX EX nA nC IIC T4 Gc; ATEX (EX) II 3G Ex nA nC IIC T4 Gc; cULus (ISA 12.12.01, CSA C22.2 No.213) Class I, Div. 2, Group ABCD, T4, File E330455 Yes; IECEX EX nA nC IIC T4 Gc No Class I, Div. 2, Group ABCD, T4 Yes Yes ABS, BV, DNV GL, LRS, NK
leakage current	3.5 mA IP20 Yes CULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus-Recognized (UL 60950-1, CSA C22.2 No. 60950-1) File E151273 Yes; ATEX (EX) II 3G Ex nA nC IIC T4 Gc IECEX EX nA nC IIC T4 Gc; ATEX (EX) II 3G Ex nA nC IIC T4 Gc; cULus (ISA 12.12.01, CSA C22.2 No.213) Class I, Div. 2, Group ABCD, T4, File E330455 Yes; IECEX Ex nA nC IIC T4 Gc No Class I, Div. 2, Group ABCD, T4 Yes Yes ABS, BV, DNV GL, LRS, NK EN 55022 Class B not applicable
leakage current	3.5 mA IP20 Yes CULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus-Recognized (UL 60950-1, CSA C22.2 No. 60950-1) File E151273 Yes; ATEX (EX) II 3G Ex nA nC IIC T4 Gc IECEX EX nA nC IIC T4 Gc; ATEX (EX) II 3G Ex nA nC IIC T4 Gc; cULus (ISA 12.12.01, CSA C22.2 No.213) Class I, Div. 2, Group ABCD, T4, File E330455 Yes; IECEX EX nA nC IIC T4 Gc No Class I, Div. 2, Group ABCD, T4 Yes Yes ABS, BV, DNV GL, LRS, NK
leakage current	3.5 mA IP20 Yes CULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus-Recognized (UL 60950-1, CSA C22.2 No. 60950-1) File E151273 Yes; ATEX (EX) II 3G Ex nA nC IIC T4 Gc IECEX EX nA nC IIC T4 Gc; ATEX (EX) II 3G Ex nA nC IIC T4 Gc; cULus (ISA 12.12.01, CSA C22.2 No.213) Class I, Div. 2, Group ABCD, T4, File E330455 Yes; IECEX Ex nA nC IIC T4 Gc No Class I, Div. 2, Group ABCD, T4 Yes Yes ABS, BV, DNV GL, LRS, NK EN 55022 Class B not applicable
leakage current	3.5 mA IP20 Yes CULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus-Recognized (UL 60950-1, CSA C22.2 No. 60950-1) File E151273 Yes; ATEX (EX) II 3G Ex nA nC IIC T4 GC IECEX EX nA nC IIC T4 GC; ATEX (EX) II 3G Ex nA nC IIC T4 GC; cULus (ISA 12.12.01, CSA C22.2 No.213) Class I, Div. 2, Group ABCD, T4, File E330455 Yes; IECEX EX nA nC IIC T4 GC No Class I, Div. 2, Group ABCD, T4 Yes Yes ABS, BV, DNV GL, LRS, NK EN 55022 Class B not applicable EN 61000-6-2
leakage current	3.5 mA IP20 Yes CULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus-Recognized (UL 60950-1, CSA C22.2 No. 60950-1) File E151273 Yes; ATEX (EX) II 3G Ex nA nC IIC T4 Gc IECEX EX nA nC IIC T4 Gc; ATEX (EX) II 3G Ex nA nC IIC T4 Gc; cULus (ISA 12.12.01, CSA C22.2 No.213) Class I, Div. 2, Group ABCD, T4, File E330455 Yes; IECEX Ex nA nC IIC T4 Gc No Class I, Div. 2, Group ABCD, T4 Yes Yes ABS, BV, DNV GL, LRS, NK EN 55022 Class B not applicable

 during transport 	-40 +85 °C	
during storage	-40 +85 °C	
Humidity class according to EN 60721	Climate class 3K3, 5 95% no condensation	
Mechanics		
Connection technology	screw-type terminals	
Connections		
 Supply input 	L, N, PE: 1 screw terminal each for 0.5 2.5 mm ²	
Output	L+, M: 2 screw terminals each for 0.5 2.5 mm ²	
Auxiliary	-	
width of the enclosure	70 mm	
height of the enclosure	100 mm	
depth of the enclosure	75 mm	
required spacing		
• top	20 mm	
bottom	20 mm	
• left	0 mm	
• right	0 mm	
Weight, approx.	0.3 kg	
product feature of the enclosure housing can be lined up	Yes	
Installation	Snaps onto DIN rail EN 60715 35x7.5/15, wall mounting	
MTBF at 40 °C	1 492 537 h	
other information	Specifications at rated input voltage and ambient temperature +25 °C (unless otherwise specified)	

