## SIEMENS

## Data sheet

## 3RN2013-1BW30



Thermistor motor protection relay Standard evaluation unit 22.5 mm enclosure screw terminal 2 change-over contacts US = 24 V-240 V AC/DC Manual/Auto/Remote reset with ATEX approval 2 LEDs (READY/TRIPPED) Safe galvanic isolation Test/reset button Wire break monitoring Short circuit monitoring non-volatile

product brand name	SIRIUS			
product category	SIRIUS 3RN2 thermistor motor protection			
product designation	Thermistor motor protection relay			
design of the product	Standard evaluation unit with ATEX approval, open-circuit and short- circuit detection in the sensor circuit, safe disconnection, non-volatile			
product type designation	3RN2			
General technical data				
product function	thermistor motor protection			
display version LED	Yes			
power loss [W] for rated value of the current				
<ul> <li>at AC in hot operating state</li> </ul>	1.7 W			
<ul> <li>at DC in hot operating state</li> </ul>	1.7 W			
insulation voltage for overvoltage category III according to IEC 60664 with degree of pollution 3 rated value	300 V			
degree of pollution	3			
surge voltage resistance rated value	6 kV			
maximum permissible voltage for safe isolation				
<ul> <li>between auxiliary and auxiliary circuit</li> </ul>	300 V			
<ul> <li>between control and auxiliary circuit</li> </ul>	300 V			
protection class IP	IP20			
shock resistance acc. to IEC 60068-2-27	11g / 15 ms			
vibration resistance acc. to IEC 60068-2-6	10 55 Hz: 0.35 mm			
mechanical service life (switching cycles) typical	10 000 000			
electrical endurance (switching cycles) at AC-15 at 230 V typical	100 000			
thermal current of the switching element with contacts maximum	5 A			
reference code acc. to IEC 81346-2	К			
Substance Prohibitance (Date)	28.05.2009			
Product Function				
product function				
error memory	Yes			
<ul> <li>dynamic open-circuit detection</li> </ul>	Yes			
external reset	Yes			
auto-RESET	Yes			
manual RESET	Yes			
Control circuit/ Control				
type of voltage of the control supply voltage	AC/DC			
control supply voltage at AC				
• at 50 Hz rated value	24 240 V			

• at 60 Hz rated value	24 240 V
at 60 Hz rated value	24 240 V
control supply voltage at DC  • rated value	24 240 V
operating range factor control supply voltage rated value at DC	24 240 V
<ul> <li>initial value</li> </ul>	0.85
<ul> <li>full-scale value</li> </ul>	1.1
operating range factor control supply voltage rated value at AC at 50 Hz	
<ul> <li>initial value</li> </ul>	0.85
full-scale value	1.1
operating range factor control supply voltage rated value at AC at 60 Hz	
<ul> <li>initial value</li> </ul>	0.85
full-scale value	1.1
inrush current peak	
• at 24 V	0.7 A
• at 240 V	12 A
duration of inrush current peak	
• at 24 V	0.25 ms
• at 240 V	0.2 ms
Measuring circuit	
buffering time in the event of power failure minimum	40 ms
Precision	
relative metering precision	2 %
Auxiliary circuit	
material of switching contacts	AgSnO2
number of NC contacts for auxiliary contacts	0
number of NO contacts for auxiliary contacts	0
number of CO contacts for auxiliary contacts	2
operational current of auxiliary contacts at DC-13	
• at 24 V	1 A
● at 125 V	0.2 A
• at 250 V	0.1 A
Main circuit	
operating frequency rated value	50 60 Hz
ampacity of the output relay at AC-15 at 250 V at 50/60 Hz	3 A
ampacity of the output relay at DC-13	
• at 24 V	1 A
• at 125 V	0.2 A
continuous current of the DIAZED fuse link of the output relay	6 A
Electromagnetic compatibility	
conducted interference	
• due to burst acc. to IEC 61000-4-4	2 kV (power ports) / 1 kV (signal ports)
<ul> <li>due to conductor-earth surge acc. to IEC 61000-4-5</li> </ul>	2 kV (line to ground)
<ul> <li>due to conductor-conductor surge acc. to IEC 61000-4-5</li> </ul>	1 kV (line to line)
electrostatic discharge acc. to IEC 61000-4-2	6 kV contact discharge / 8 kV air discharge
Galvanic isolation	
design of the electrical isolation	Protective separation
galvanic isolation	
<ul> <li>between input and output</li> </ul>	Yes
<ul> <li>between the outputs</li> </ul>	Yes
<ul> <li>between the voltage supply and other circuits</li> </ul>	Yes
Safety related data	
Safety Integrity Level (SIL) acc. to IEC 61508	1
performance level (PL) acc. to EN ISO 13849-1	C
category acc. to EN ISO 13849-1	1
Safe failure fraction (SFF)	74 %

	40.0/			
average diagnostic coverage level (DCavg)	18 %			
failure rate [FIT]	0.00000000 4/h			
<ul> <li>at rate of recognizable hazardous failures (λdd)</li> <li>at rate of non recognizable hazardous failures (λdu)</li> </ul>	0.00000068 1/h			
• at rate of non-recognizable hazardous failures ( $\lambda$ du)	0.00000031 1/h			
PFHD with high demand rate acc. to EN 62061	0.00000038 1/h 0.0041			
PFDavg with low demand rate acc. to IEC 61508 MTBF				
MTTFd	97 y 202 y			
hardware fault tolerance acc. to IEC 61508	0			
T1 value for proof test interval or service life acc. to	3 y			
IEC 61508	S y			
Connections/ Terminals				
product component removable terminal for auxiliary and control circuit	Yes			
type of electrical connection	screw-type terminals			
<ul> <li>for auxiliary and control circuit</li> </ul>	screw-type terminals			
type of connectable conductor cross-sections				
• solid	1x (0.5 4.0 mm²), 2x (0.5 2.5 mm²)			
<ul> <li>finely stranded with core end processing</li> </ul>	1x (0.5 4 mm²), 2x (0.5 1.5 mm²)			
<ul> <li>at AWG cables solid</li> </ul>	1x (20 12), 2x (20 14)			
connectable conductor cross-section				
• solid	0.5 4 mm²			
<ul> <li>finely stranded with core end processing</li> </ul>	0.5 4 mm²			
AWG number as coded connectable conductor cross section				
• solid	20 12			
stranded	20 12			
tightening torque with screw-type terminals	0.6 0.8 N·m			
Installation/ mounting/ dimensions				
mounting position	any			
fastening method	screw and snap-on mounting onto 35 mm standard mounting rail			
height	100 mm			
width	22.5 mm			
depth	90 mm			
depth required spacing				
depth required spacing • with side-by-side mounting	90 mm			
depth         required spacing         • with side-by-side mounting         — forwards	90 mm 0 mm			
depth         required spacing         • with side-by-side mounting         — forwards         — backwards	90 mm 0 mm 0 mm			
depth         required spacing         • with side-by-side mounting         — forwards         — backwards         — upwards	90 mm 0 mm 0 mm 0 mm			
depth         required spacing         • with side-by-side mounting         — forwards         — backwards         — upwards         — downwards	90 mm 0 mm 0 mm 0 mm 0 mm			
depth         required spacing         • with side-by-side mounting         — forwards         — backwards         — upwards         — downwards         — at the side	90 mm 0 mm 0 mm 0 mm			
depth         required spacing         • with side-by-side mounting         — forwards         — backwards         — upwards         — downwards         — at the side         • for grounded parts	90 mm 0 mm 0 mm 0 mm 0 mm 0 mm			
depth         required spacing         • with side-by-side mounting         — forwards         — backwards         — upwards         — downwards         — at the side         • for grounded parts         — forwards	90 mm 0 mm 0 mm 0 mm 0 mm 0 mm 0 mm			
depth         required spacing         • with side-by-side mounting         — forwards         — backwards         — upwards         — downwards         — at the side         • for grounded parts         — backwards         — backwards	90 mm 0 mm 0 mm 0 mm 0 mm 0 mm 0 mm 0 mm			
depth         required spacing         • with side-by-side mounting         — forwards         — backwards         — upwards         — downwards         — at the side         • for grounded parts         — forwards         — backwards         — upwards	90 mm 0 mm 0 mm 0 mm 0 mm 0 mm 0 mm 0 mm 0 mm 0 mm			
depth         required spacing         • with side-by-side mounting         — forwards         — backwards         — upwards         — downwards         — at the side         • for grounded parts         — forwards         — backwards         — upwards         — forwards         — at the side         • for grounded parts         — forwards         — backwards         — upwards         — at the side	90 mm 0 mm			
depth         required spacing         • with side-by-side mounting         — forwards         — backwards         — upwards         — downwards         — at the side         • for grounded parts         — forwards         — backwards         — at the side         • for grounded parts         — forwards         — upwards         — at the side         — at the side         — at the side         — downwards	90 mm 0 mm 0 mm 0 mm 0 mm 0 mm 0 mm 0 mm 0 mm 0 mm			
depth         required spacing         • with side-by-side mounting         — forwards         — backwards         — upwards         — downwards         — at the side         • for grounded parts         — forwards         — backwards         — upwards         — forwards         — at the side         • for grounded parts         — forwards         — backwards         — upwards         — at the side	90 mm 0 mm			
depth         required spacing         • with side-by-side mounting         — forwards         — backwards         — upwards         — downwards         — at the side         • for grounded parts         — forwards         — backwards         — upwards         — forwards         — backwards         — forwards         — backwards         — upwards         — at the side         — downwards         • for live parts         — forwards	90 mm 0 mm			
depth         required spacing         • with side-by-side mounting         — forwards         — backwards         — upwards         — downwards         — at the side         • for grounded parts         — forwards         — backwards         — upwards         — forwards         — loackwards         — upwards         — odownwards         • for live parts         — forwards         — backwards         • for live parts         — backwards         — backwards	90 mm 0 mm			
depth         required spacing         • with side-by-side mounting         — forwards         — backwards         — upwards         — downwards         — at the side         • for grounded parts         — forwards         — backwards         — upwards         — forwards         — backwards         — forwards         — backwards         — upwards         — at the side         — downwards         • for live parts         — forwards	90 mm 0 mm			
depth         required spacing         • with side-by-side mounting         — forwards         — backwards         — upwards         — downwards         — at the side         • for grounded parts         — forwards         — backwards         — upwards         — forwards         — backwards         — upwards         — for live parts         — forwards         — backwards         — upwards         — upwards         • for live parts         — upwards         — upwards         — upwards         — upwards         — upwards	90 mm 0 mm			
depth         required spacing         • with side-by-side mounting         — forwards         — backwards         — upwards         — downwards         — at the side         • for grounded parts         — forwards         — backwards         — at the side         • for grounded parts         — forwards         — backwards         — upwards         — downwards         • for live parts         — forwards         — backwards         — upwards         — downwards         — at the side         — downwards         — at the side         — upwards         — upwards         — horkwards         — upwards         — upwards	90 mm 0 mm			
depth         required spacing         • with side-by-side mounting         — forwards         — backwards         — upwards         — downwards         — at the side         • for grounded parts         — forwards         — backwards         — upwards         — backwards         — upwards         — forwards         — downwards         • for live parts         — forwards         — backwards         — upwards         — at the side         — downwards         • for live parts         — forwards         — upwards         — at the side         — downwards         — at the side	90 mm 0 mm			
depth         required spacing         • with side-by-side mounting         - forwards         - backwards         - upwards         - downwards         - at the side         • for grounded parts         - forwards         - backwards         - upwards         - backwards         - upwards         - backwards         - at the side         - downwards         • for live parts         - forwards         - backwards         - upwards         - at the side         - downwards         - for live parts         - forwards         - backwards         - upwards         - at the side         Mbient conditions         installation altitude at height above sea level maximum	90 mm 0 mm			
depth         required spacing         • with side-by-side mounting         - forwards         - backwards         - upwards         - at the side         • for grounded parts         - forwards         - backwards         - backwards         - at the side         • for grounded parts         - forwards         - backwards         - upwards         - at the side         - downwards         • for live parts         - forwards         - backwards         - upwards         - downwards         • for live parts         - forwards         - upwards         - at the side         Mounwards         - at the side         - at the side         Mounwards         - at the side         Mounwards         - at the side         Ambient conditions         installation altitude at height above sea level maximum	90 mm 0 mm			
depth         required spacing         • with side-by-side mounting         - forwards         - backwards         - upwards         - downwards         - at the side         • for grounded parts         - forwards         - backwards         - at the side         • for grounded parts         - forwards         - backwards         - upwards         - at the side         - downwards         • for live parts         - forwards         - backwards         - upwards         - downwards         - forwards         - backwards         - upwards         - backwards         - upwards         - at the side         Mounwards         - at the side         Mounwards         - at the side         Mounwards         - at the side         - downwards         - at the side         Mounwards         - at the side         - downwards         - at the side         - during operation	90 mm 0 mm			
depth         required spacing         • with side-by-side mounting         - forwards         - backwards         - upwards         - downwards         - at the side         • for grounded parts         - forwards         - backwards         - at the side         • for grounded parts         - forwards         - backwards         - upwards         - at the side         - downwards         • for live parts         - forwards         - backwards         - upwards         - at the side         - downwards         - backwards         - upwards         - backwards         - upwards         - at the side         Motiont conditions         installation altitude at height above sea level maximum         ambient temperature         • during operation         • during storage	90 mm 0 mm			
depth         required spacing         • with side-by-side mounting         - forwards         - backwards         - upwards         - downwards         - at the side         • for grounded parts         - forwards         - backwards         - at the side         • for grounded parts         - forwards         - backwards         - upwards         - at the side         - downwards         • for live parts         - forwards         - backwards         - upwards         - downwards         - forwards         - backwards         - upwards         - backwards         - upwards         - at the side         Mounwards         - at the side         Mounwards         - at the side         Mounwards         - at the side         - downwards         - at the side         Mounwards         - at the side         - downwards         - at the side         - during operation	90 mm 0 mm			

	xplosion protection category for dust xplosion protection category for gas		[Ex t] [Ex p] [Ex e] [Ex d] [Ex px]		
Certificates/ approva General Product A				EMC	For use in hazard- ous locations
SP.			EHC	RCM	K ATEX
Declaration of Conformity	Test Certificates	Marine / Shipping			other
CE EG-Konf.	<u>Type Test Certific-</u> ates/Test Report	Lloyds Register uis	PRS	DINV-GL DINV-GL	<u>Confirmation</u>

## Further information

Information- and Downloadcenter (Catalogs, Brochures,...)

https://www.siemens.com/ic10

Industry Mall (Online ordering system)

https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=3RN2013-1BW30

Cax online generator

http://support.automation.siemens.com/WW/CAXorder/default.aspx?lang=en&mlfb=3RN2013-1BW30

Service&Support (Manuals, Certificates, Characteristics, FAQs,...)


https://support.industry.siemens.com/cs/ww/en/ps/3RN2013-1BW30


Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, EPLAN macros, ...)

http://www.automation.siemens.com/bilddb/cax\_de.aspx?mlfb=3RN2013-1BW30&lang=en

**Characteristic: Derating** 

https://support.industry.siemens.com/cs/ww/en/ps/3RN2013-1BW30/manual





last modified:

5/1/2021 🖸