Data sheet 6ES7511-1FK02-0AB0



SIMATIC S7-1500F, CPU 1511F-1 PN, CENTRAL PROCESSING UNIT WITH WITH WORKING MEMORY 225 KB FOR PROGRAM AND 1 MB FOR DATA, 1. INTERFACE: PROFINET IRT WITH 2 PORT SWITCH, 60 NS BIT-PERFORMANCE, SIMATIC MEMORY CARD NECESSARY

General information	
Product type designation	CPU 1511F-1 PN
HW functional status	FS03
Firmware version	V2.9
Product function	
 I&M data 	Yes; I&M0 to I&M3
Isochronous mode	Yes; Distributed and central; with minimum OB $6x$ cycle of $625~\mu s$ (distributed) and $1~ms$ (central)
Engineering with	
 STEP 7 TIA Portal configurable/integrated from version 	V17 (FW V2.9) / V15 (FW V2.5) or higher; with older TIA Portal versions configurable as 6ES7511-1FK01-0AB0
Configuration control	
via dataset	Yes
Display	
Screen diagonal [cm]	3.45 cm
Control elements	
Number of keys	8
Mode buttons	2
Supply voltage	
Rated value (DC)	24 V
permissible range, lower limit (DC)	19.2 V
permissible range, upper limit (DC)	28.8 V
Reverse polarity protection	Yes
Mains buffering	
 Mains/voltage failure stored energy time 	5 ms
Repeat rate, min.	1/s
Input current	
Current consumption (rated value)	0.7 A
Current consumption, max.	0.95 A
Inrush current, max.	1.9 A; Rated value
l²t	0.02 A ² ·s
Power	
Infeed power to the backplane bus	10 W
Power consumption from the backplane bus (balanced)	5.5 W
Power loss	
Power loss, typ.	5.7 W
Memory	
Number of slots for SIMATIC memory card	1
SIMATIC memory card required	Yes

Mark magazin	
Work memory	205 khyto
• integrated (for program)	225 kbyte
• integrated (for data)	1 Mbyte
Load memory	22 Chuta
Plug-in (SIMATIC Memory Card), max. Pagiture	32 Gbyte
Backup maintenance-free	Yes
1 11 11 11 11	Tes
CPU processing times	00
for bit operations, typ.	60 ns
for word operations, typ.	72 ns 96 ns
for fixed point arithmetic, typ.	
for floating point arithmetic, typ. CPU-blocks	384 ns
	4 000) Planks (OR ER EQ DR) and URTs
Number of elements (total) DB	4 000; Blocks (OB, FB, FC, DB) and UDTs
	1 CO 000; subdivided into number range that can be used by the
Number range	1 60 999; subdivided into: number range that can be used by the user: 1 59 999, and number range of DBs created via SFC 86: 60 000 60 999
• Size, max.	1 Mbyte; For DBs with absolute addressing, the max. size is 64 KB
FB	
Number range	0 65 535
• Size, max.	150 kbyte
FC	
Number range	0 65 535
• Size, max.	150 kbyte
ОВ	
• Size, max.	150 kbyte
 Number of free cycle OBs 	100
 Number of time alarm OBs 	20
 Number of delay alarm OBs 	20
 Number of cyclic interrupt OBs 	20; With minimum OB 3x cycle of 500 μs
 Number of process alarm OBs 	50
 Number of DPV1 alarm OBs 	3
 Number of isochronous mode OBs 	2
 Number of technology synchronous alarm OBs 	2
 Number of startup OBs 	100
 Number of asynchronous error OBs 	4
 Number of synchronous error OBs 	2
Number of diagnostic alarm OBs	1
Nesting depth	
per priority class	24; Up to 8 possible for F-blocks
Counters, timers and their retentivity	
S7 counter	
Number	2 048
Retentivity	
— adjustable	Yes
IEC counter	
Number	Any (only limited by the main memory)
Retentivity	
— adjustable	Yes
S7 times	
• Number	2 048
Retentivity	V.
— adjustable	Yes
IEC timer	
• Number	Any (only limited by the main memory)
Retentivity	V
— adjustable	Yes
Data areas and their retentivity	
Retentive data area (incl. timers, counters, flags), max.	128 kbyte; In total; available retentive memory for bit memories, timers,

	counters DDs and technology data (avec) 00 KD
Extended retentive data area (incl. timera accordance file and	counters, DBs, and technology data (axes): 88 KB
Extended retentive data area (incl. timers, counters, flags), max.	1 Mbyte; When using PS 6 0W 24/48/60 V DC HF
Flag	
• Size, max.	16 kbyte
Number of clock memories	8; 8 clock memory bit, grouped into one clock memory byte
Data blocks	o, o dook memory bit, grouped into one dook memory byte
Retentivity adjustable	Yes
Retentivity preset	No
Local data	110
per priority class, max.	64 kbyte; max. 16 KB per block
Address area	04 Royte, max. 10 Ro per block
	4004
Number of IO modules	1 024; max. number of modules / submodules
I/O address area	0011 (411: (: 11
• Inputs	32 kbyte; All inputs are in the process image
• Outputs	32 kbyte; All outputs are in the process image
per integrated IO subsystem	
— Inputs (volume)	8 kbyte
— Outputs (volume)	8 kbyte
per CM/CP	
— Inputs (volume)	8 kbyte
— Outputs (volume)	8 kbyte
Subprocess images	
Number of subprocess images, max.	32
Hardware configuration	
Number of distributed IO systems	32; A distributed I/O system is characterized not only by the integration of distributed I/O via PROFINET or PROFIBUS communication modules, but also by the connection of I/O via AS-i master modules or links (e.g. IE/PB-Link)
Number of DP masters	
• Via CM	4; A maximum of 4 CMs/CPs (PROFIBUS, PROFINET, Ethernet) can be inserted in total
Number of IO Controllers	
integrated	1
• Via CM	4; A maximum of 4 CMs/CPs (PROFIBUS, PROFINET, Ethernet) can be inserted in total
Rack	
 Modules per rack, max. 	32; CPU + 31 modules
Number of lines, max.	1
PtP CM	
Number of PtP CMs	the number of connectable PtP CMs is only limited by the number of available slots
Time of day	
Clock	
• Type	Hardware clock
Backup time	6 wk; At 40 °C ambient temperature, typically
Deviation per day, max.	10 s; Typ.: 2 s
Operating hours counter	
Number	16
Clock synchronization	
• supported	Yes
• in AS, master	Yes
• in AS, slave	Yes
on Ethernet via NTP	Yes
nterfaces	
Number of PROFINET interfaces	1
I. Interface	
Interface types	VV4
• RJ 45 (Ethernet)	Yes; X1
Number of ports	2
integrated switch	Yes

Protocols	
IP protocol	Yes; IPv4
 PROFINET IO Controller 	Yes
 PROFINET IO Device 	Yes
 SIMATIC communication 	Yes
 Open IE communication 	Yes; Optionally also encrypted
Web server	Yes
 Media redundancy 	Yes; MRP Automanager according to IEC 62439-2 Edition 2.0
PROFINET IO Controller	
Services	
— PG/OP communication	Yes
 Isochronous mode 	Yes
 Direct data exchange 	Yes; Requirement: IRT and isochronous mode (MRPD optional)
— IRT	Yes
— PROFlenergy	Yes; per user program
 Prioritized startup 	Yes; Max. 32 PROFINET devices
 Number of connectable IO Devices, max. 	128; In total, up to 256 distributed I/O devices can be connected via AS-i, PROFIBUS or PROFINET
 Of which IO devices with IRT, max. 	64
 Number of connectable IO Devices for RT, max. 	128
— of which in line, max.	128
 Number of IO Devices that can be simultaneously activated/deactivated, max. 	8; in total across all interfaces
 Number of IO Devices per tool, max. 	8
— Updating times	The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data
Update time for IRT	
— for send cycle of 250 μs	$250\ \mu s$ to 4 ms; Note: In the case of IRT with isochronous mode, the
— for send cycle of 500 μs	minimum update time of 625 μs of the isochronous OB is decisive 500 μs to 8 ms; Note: In the case of IRT with isochronous mode, the minimum update time of 625 μs of the isochronous OB is decisive
— for send cycle of 1 ms	1 ms to 16 ms
— for send cycle of 2 ms	2 ms to 32 ms
— for send cycle of 4 ms	4 ms to 64 ms
 With IRT and parameterization of "odd" send 	Update time = set "odd" send clock (any multiple of 125 μs: 375 μs, 625
cycles	μs 3 875 μs)
Update time for RT	
— for send cycle of 250 μs	250 μs to 128 ms
— for send cycle of 500 μs	500 μs to 256 ms
— for send cycle of 1 ms	1 ms to 512 ms
— for send cycle of 2 ms	2 ms to 512 ms
— for send cycle of 4 ms	4 ms to 512 ms
PROFINET IO Device	
Services	
— PG/OP communication	Yes
 Isochronous mode 	No
— IRT	Yes
— PROFlenergy	Yes; per user program
 Shared device 	Yes
 Number of IO Controllers with shared device, max. 	4
 activation/deactivation of I-devices 	Yes; per user program
— Asset management record	Yes; per user program
Interface types	
RJ 45 (Ethernet)	
• 100 Mbps	Yes
 Autonegotiation 	Yes
 Autocrossing 	Yes
 Industrial Ethernet status LED 	Yes
Protocols	

PROFIsafe	Yes; V2.4 / V2.6
Number of connections	
Number of connections, max.	96; via integrated interfaces of the CPU and connected CPs / CMs
 Number of connections reserved for ES/HMI/web 	10
 Number of connections via integrated interfaces 	64
Number of S7 routing paths	16
Redundancy mode	
H-Sync forwarding	Yes
Media redundancy	
— Media redundancy	only via 1st interface (X1)
— MRP	Yes; MRP Automanager according to IEC 62439-2 Edition 2.0, MRP
1411.0	Manager; MRP Client
 MRP interconnection, supported 	Yes; as MRP ring node according to IEC 62439-2 Edition 3.0
— MRPD	Yes; Requirement: IRT
 Switchover time on line break, typ. 	200 ms; For MRP, bumpless for MRPD
Number of stations in the ring, max.	50
SIMATIC communication	00
PG/OP communication	Yes; encryption with TLS V1.3 pre-selected
	Yes
S7 communication, as server.	Yes
S7 communication, as server S7 communication, as slight.	
S7 communication, as client	Yes
User data per job, max.	See online help (S7 communication, user data size)
Open IE communication	
• TCP/IP	Yes
— Data length, max.	64 kbyte
 — several passive connections per port, supported 	Yes
• ISO-on-TCP (RFC1006)	Yes
— Data length, max.	64 kbyte
• UDP	Yes
— Data length, max.	2 kbyte; 1 472 bytes for UDP broadcast
UDP multicast	Yes; Max. 5 multicast circuits
• DHCP	Yes
• DNS	Yes
• SNMP	Yes
• DCP	Yes
• LLDP	Yes
Encryption	Yes; Optional
Web server	
• HTTP	Yes; Standard and user pages
• HTTPS	Yes; Standard and user pages
OPC UA	- roo, otaliaala alla aoo. pagoo
Runtime license required	Yes
OPC UA Client	Yes
Application authentication	Yes
Application authentication Security policies	
— Security policies	Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256
— User authentication	"anonymous" or by user name & password
Number of connections, max.	4
Number of connections, max. Number of nodes of the client interfaces, max.	1 000
Number of flowes of the client interfaces, max. Number of elements for one call of	300
OPC_UA_NodeGetHandleList/OPC_UA_ReadList/C max.	
 Number of elements for one call of OPC_UA_NameSpaceGetIndexList, max. 	20
Number of elements for one call of OPC_UA_MethodGetHandleList, max.	100
 Number of simultaneous calls of the client instructions per connection (except 	1
OPC_UA_ReadList,OPC_UA_WriteList,OPC_UA_M max.	
 Number of simultaneous calls of the client 	5

OPC_UA_ReadList,OPC_UA_WriteList and	
OPC_UA_MethodCall, max.	
 Number of registerable nodes, max. 	5 000
 Number of registerable method calls of OPC_UA_MethodCall, max. 	100
 — Number of inputs/outputs when calling OPC_UA_MethodCall, max. 	20
OPC UA Server	Yes; Data access (read, write, subscribe), method call, custom address space
 Application authentication 	Yes
— Security policies	Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256
 User authentication 	"anonymous" or by user name & password
 Number of sessions, max. 	32
 Number of accessible variables, max. 	50 000
 Number of registerable nodes, max. 	10 000
 Number of subscriptions per session, max. 	20
— Sampling interval, min.	100 ms
Publishing interval, min.	500 ms
Number of server methods, max.	20
Number of inputs/outputs per server method,	20
max.	
 Number of monitored items, max. 	1 000; for 1 s sampling interval and 1 s send interval
 Number of server interfaces, max. 	10 of each "Server interfaces" / "Companion specification" type and 20 of the type "Reference namespace"
 Number of nodes for user-defined server interfaces, max. 	1 000
Further protocols	
MODBUS	Yes; MODBUS TCP
Isochronous mode	
Equidistance	Yes
C7 manage functions	
57 message functions	
S7 message functions Number of login stations for message functions may	32
Number of login stations for message functions, max.	32 Ves
Number of login stations for message functions, max. Program alarms	Yes
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max.	Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max.	Yes 5 000; Program messages are generated by the "Program_Alarm"
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms	Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms	Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics	Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms	Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics	Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects	Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions	Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 80
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering)	Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 80 Yes; Parallel online access possible for up to 5 engineering systems
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block	Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 80 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients)
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step	Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 80 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints	Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 80 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control	Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 80 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control Status/control variable	Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 80 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe),
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control Status/control variable Variables	Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 80 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe),
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control Status/control Status/control variable Variables Number of variables, max.	Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 80 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control Status/control Status/control variable Variables Number of variables, max. — of which status variables, max.	Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 80 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters 200; per job
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control Status/control Status/control variable Variables Number of variables, max. — of which status variables, max. — of which control variables, max.	Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 80 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters 200; per job
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control Status/control Variables Number of variables, max. of which status variables, max. of which control variables, max. Forcing	Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 80 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters 200; per job 200; per job
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control Status/control Status/control variable Variables Number of variables, max. of which status variables, max. of which control variables, max. Forcing Forcing	Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 80 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters 200; per job 200; per job Yes; without fail-safe
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control Status/control Status/control variable Variables Number of variables, max. of which status variables, max. of which control variables, max. Forcing Forcing Forcing Forcing, variables	Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 80 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters 200; per job 200; per job Yes; without fail-safe peripheral inputs/outputs (without fail-safe)
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control Status/control Status/control Status/control variable Variables Number of variables, max. of which status variables, max. Forcing Forcing Forcing Forcing Forcing, variables, max.	Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 80 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters 200; per job 200; per job Yes; without fail-safe peripheral inputs/outputs (without fail-safe)
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control Status/control Status/control variable Variables Number of variables, max. of which status variables, max. Forcing Forcing Forcing Forcing, variables, max. Number of variables, max.	Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 80 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters 200; per job 200; per job Yes; without fail-safe peripheral inputs/outputs (without fail-safe) 200
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control Status/control Status/control variable Variables Number of variables, max. of which status variables, max. forcing Forcing Forcing Forcing, variables Number of variables, max. Diagnostic buffer present	Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 80 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters 200; per job 200; per job Yes; without fail-safe peripheral inputs/outputs (without fail-safe) 200 Yes

Number of configurable Traces	4; Up to 512 KB of data per trace are possible
Interrupts/diagnostics/status information	,
Diagnostics indication LED	
RUN/STOP LED	Yes
• ERROR LED	Yes
MAINT LED	Yes
STOP ACTIVE LED	Yes
 Connection display LINK TX/RX 	Yes
Supported technology objects	
Motion Control	Yes; Note: The number of technology objects affects the cycle time of
	the PLC program; selection guide via the TIA Selection Tool
Number of available Motion Control resources for	800
technology objects	
Required Motion Control resources	40
— per speed-controlled axis	40
— per positioning axis	80
— per synchronous axis	160
— per external encoder	80 20
— per output cam	160
— per cam track — per probe	40
Positioning axis	10
Number of positioning axes at motion control	5
cycle of 4 ms (typical value)	
Number of positioning axes at motion control	10
cycle of 8 ms (typical value)	
Controller	
PID_Compact	Yes; Universal PID controller with integrated optimization
PID_3Step	Yes; PID controller with integrated optimization for valves
PID-Temp	Yes; PID controller with integrated optimization for temperature
Counting and measuring	
High-speed counter	Yes
Standards, approvals, certificates	
Highest safety class achievable in safety mode	
 Performance level according to ISO 13849-1 	PLe
SIL acc. to IEC 61508	SIL 3
Probability of failure (for service life of 20 years and repair	
 Low demand mode: PFDavg in accordance with SIL3 	< 2.00E-05
High demand/continuous mode: PFH in accordance with SIL3	< 1.00E-09
Ambient conditions	
Ambient temperature during operation	
horizontal installation, min.	-25 °C; No condensation
horizontal installation, max.	60 °C; Display: 50 °C, at an operating temperature of typically 50 °C, the
•	display is switched off
 vertical installation, min. 	-25 °C; No condensation
• vertical installation, max.	40 °C; Display: 40 °C, at an operating temperature of typically 40 °C, the display is switched off
Ambient temperature during storage/transportation	alopidy to switched on
min.	-40 °C
• max.	70 °C
Altitude during operation relating to sea level	
Installation altitude above sea level, max.	5 000 m; Restrictions for installation altitudes > 2 000 m, see manual
configuration / header	The state of the s
configuration / programming / header	
Programming language	
— LAD	Yes; incl. failsafe
— FBD	Yes; incl. failsafe
— PBD — STL	Yes
— STL — SCL	Yes
— 00 L	100

— GRAPH	Yes
Know-how protection	
 User program protection/password protection 	Yes
 Copy protection 	Yes
Block protection	Yes
Access protection	
 Password for display 	Yes
 Protection level: Write protection 	Yes; Specific write protection both for Standard and for Failsafe
 Protection level: Read/write protection 	Yes
 Protection level: Write protection for Failsafe 	Yes
Protection level: Complete protection	Yes
programming / cycle time monitoring / header	
• lower limit	adjustable minimum cycle time
• upper limit	adjustable maximum cycle time
Dimensions	
Width	35 mm
Height	147 mm
Depth	129 mm
Weights	
Weight, approx.	405 g

last modified:

11/3/2021 🖸