## **Data sheet**

## 6ES7134-6PA01-0BD0



SIMATIC ET 200SP, Analog input module, AI Energy Meter 400 V AC ST, suitable for BU type D0, channel diagnostics

General information	
Product type designation	Al energy meter 400VAC ST
Firmware version	V3.0
usable BaseUnits	BU type D0
Product function	
<ul> <li>Voltage measurement</li> </ul>	Yes
<ul> <li>— with voltage transformer</li> </ul>	No
<ul> <li>Current measurement</li> </ul>	Yes
<ul> <li>— without current transformer</li> </ul>	No
<ul> <li>— with current transformer</li> </ul>	Yes
<ul> <li>Energy measurement</li> </ul>	Yes
<ul> <li>Frequency measurement</li> </ul>	Yes
<ul> <li>Power measurement</li> </ul>	Yes
<ul> <li>Active power measurement</li> </ul>	Yes
<ul> <li>Reactive power measurement</li> </ul>	Yes
I&M data	Yes; I&M0 to I&M3
<ul> <li>Isochronous mode</li> </ul>	No
Engineering with	
<ul> <li>STEP 7 TIA Portal configurable/integrated from version</li> </ul>	V13 SP1
<ul> <li>STEP 7 configurable/integrated from version</li> </ul>	V5.5 SP4 and higher
<ul> <li>PROFIBUS from GSD version/GSD revision</li> </ul>	GSD Revision 5
<ul> <li>PROFINET from GSD version/GSD revision</li> </ul>	V2.3
Operating mode	
<ul> <li>cyclic measurement</li> </ul>	Yes
<ul> <li>acyclic measurement</li> </ul>	Yes
<ul> <li>Acyclic measured value access</li> </ul>	Yes
<ul> <li>Fixed measured value sets</li> </ul>	Yes
<ul> <li>Freely definable measured value sets</li> </ul>	No
CiR - Configuration in RUN	
Reparameterization possible in RUN	Yes
Calibration possible in RUN	No
Installation type/mounting	
Mounting position	any
Supply voltage	
Design of the power supply	Supply via voltage measurement channel L1
Rated value (AC)	100 - 240 V AC
permissible range, lower limit (AC)	90 V
permissible range, upper limit (AC)	264 V

Line frequency	
<ul> <li>permissible range, lower limit</li> </ul>	47 Hz
permissible range, upper limit	63 Hz
Power loss	
Power loss, typ.	0.6 W
Address area	
Address space per module	
<ul> <li>Address space per module, max.</li> </ul>	44 byte; 32 byte input / 12 byte output
Hardware configuration	
Automatic encoding	
Mechanical coding element	Yes
Type of mechanical coding element	type C
Time of day	
Operating hours counter	
• present	No
·	110
Analog inputs  Civile time (all phannels) time	50 may Time for consistent undete of all magazined and aclaulated
Cycle time (all channels), typ.	50 ms; Time for consistent update of all measured and calculated values (cyclic und acyclic data)
Interrupts/diagnostics/status information	
Alarms	
Diagnostic alarm	Yes
Limit value alarm	No
Hardware interrupt	No
Diagnostics indication LED	
Monitoring of the supply voltage (PWR-LED)	Yes
Channel status display	Yes; green LED
• for channel diagnostics	Yes; red Fn LED
for module diagnostics	Yes; green/red DIAG LED
Integrated Functions	100, 9100111100 211110 222
Measuring functions	
Measuring procedure for voltage measurement	TRMS
Measuring procedure for current measurement	TRMS
Type of measured value acquisition	seamless
Curve shape of voltage	Sinusoidal or distorted
Buffering of measured variables	No
Parameter length	38 byte
Bandwidth of measured value acquisition	2 kHz; Harmonics: 39 / 50 Hz, 32 / 60 Hz
Measuring range	2 KHZ, HAITHOHICS. 35 / 30 HZ, 32 / 00 HZ
Frequency measurement, min.	45 Hz
Frequency measurement, min.  Frequency measurement, max.	65 Hz
— Frequency measurement, max.  Measuring inputs for voltage	05 HZ
Measurable line voltage between phase and	230 V
neutral conductor  — Measurable line voltage between the line	400 V
conductors  — Measurable line voltage between phase and	90 V
neutral conductor, min.  — Measurable line voltage between phase and	264 V
neutral conductor, max.  — Measurable line voltage between the line	155 V
conductors, min.	
Measurable line voltage between the line conductors, max.	460 V
Internal resistance line conductor and neutral conductor	3.4 ΜΩ
— Power consumption per phase	20 mW
<ul> <li>Impulse voltage resistance 1,2/50µs</li> </ul>	1 kV
-	
<ul> <li>Measurement category for voltage measurement in accordance with IEC 61010-2- 030</li> </ul>	CAT II; CAT III in case of guaranteed protection level of 1.5 kV
measurement in accordance with IEC 61010-2-	CAT II; CAT III in case of guaranteed protection level of 1.5 kV

— measurable relative current (AC), min.	5 %; Relative to the secondary rated current; 1 A, 5 A
<ul> <li>measurable relative current (AC), max.</li> </ul>	100 %; Relative to the secondary rated current; 1 A, 5 A
<ul> <li>Continuous current with AC, maximum permissible</li> </ul>	5 A
<ul> <li>Apparent power consumption per phase for measuring range 5 A</li> </ul>	0.6 VA
<ul> <li>Rated value short-time withstand current restricted to 1 s</li> </ul>	100 A
<ul> <li>— Input resistance measuring range 0 to 5 A</li> </ul>	25 mΩ; At the terminal
<ul><li>— Surge strength</li></ul>	10 A; for 1 minute
<ul><li>Zero point suppression</li></ul>	Parameterizable: 20 250 mA, default 50 mA
Accuracy class according to IEC 61557-12	
<ul> <li>Measured variable voltage</li> </ul>	0.5
<ul> <li>Measured variable current</li> </ul>	0.5
<ul> <li>Measured variable apparent power</li> </ul>	1
<ul> <li>Measured variable active power</li> </ul>	1
<ul> <li>Measured variable reactive power</li> </ul>	1
<ul> <li>Measured variable power factor</li> </ul>	0.5
<ul> <li>Measured variable active energy</li> </ul>	1
<ul> <li>Measured variable reactive energy</li> </ul>	2
<ul> <li>Measured variable phase angle</li> </ul>	±1 °; not covered by IEC 61557-12
<ul> <li>Measured variable frequency</li> </ul>	0.05
Potential separation	
Potential separation channels	
<ul> <li>between the channels and backplane bus</li> </ul>	Yes; 3 700V AC (type test) CAT III
Isolation	
Isolation tested with	2 300V AC for 1 min. (type test)
Ambient conditions	
Ambient temperature during operation	
<ul> <li>horizontal installation, min.</li> </ul>	0 °C
<ul> <li>horizontal installation, max.</li> </ul>	60 °C
<ul> <li>vertical installation, min.</li> </ul>	0 °C
vertical installation, max.	50 °C
Dimensions	
Width	20 mm
Height	73 mm
Depth	58 mm
Weights	
Weight, approx.	45 g
Other	
Data for selecting a current transformer	
<ul> <li>Burden power current transformer x/1A, min.</li> </ul>	As a function of cable length and cross section, see device manual
<ul> <li>Burden power current transformer x/5A, min.</li> </ul>	As a function of aphia langth and areas action, and device manual
	As a function of cable length and cross section, see device manual