## **SIEMENS**

## **Data sheet**



SIMATIC DP, CPU 1512SP F-1 PN for ET 200SP, Central processing unit with Work memory 300 KB for program and 1 MB for data, 1st interface: PROFINET IRT with 3-port switch, 48 ns bit performance, SIMATIC Memory Card required, BusAdapter required for Port 1 and 2

General information	
Product type designation	CPU 1512SP F-1 PN
HW functional status	FS05
Firmware version	V2.9
Product function	
<ul><li>I&amp;M data</li></ul>	Yes; I&M0 to I&M3
<ul> <li>Module swapping during operation (hot swapping)</li> </ul>	Yes; Multi-hot swapping
Isochronous mode	Yes; Only with PROFINET; with minimum OB 6x cycle of 625 µs
Engineering with	
<ul> <li>STEP 7 TIA Portal configurable/integrated from version</li> </ul>	V17 (FW V2.9) / V13 SP1 Update 4 (FW V1.8) or higher
Configuration control	
via dataset	Yes
Control elements	
Mode selector switch	1
Supply voltage	
Rated value (DC)	24 V
permissible range, lower limit (DC)	19.2 V
permissible range, upper limit (DC)	28.8 V
Reverse polarity protection	Yes
Mains buffering	
<ul> <li>Mains/voltage failure stored energy time</li> </ul>	5 ms
Input current	
Current consumption (rated value)	0.6 A
Current consumption, max.	0.9 A
Inrush current, max.	4.7 A; Rated value
l²t	0.14 A <sup>2</sup> ·s
Power	
Infeed power to the backplane bus	8.75 W
Power loss	
Power loss, typ.	5.6 W
Memory	
Number of slots for SIMATIC memory card	1
SIMATIC memory card required	Yes
Work memory	
• integrated (for program)	300 kbyte
integrated (for data)	1 Mbyte
Load memory	
<ul> <li>Plug-in (SIMATIC Memory Card), max.</li> </ul>	32 Gbyte

Backup	
maintenance-free	Yes
CPU processing times	165
for bit operations, typ.	48 ns
for word operations, typ.	58 ns
for fixed point arithmetic, typ.	77 ns
for floating point arithmetic, typ.	307 ns
CPU-blocks	307 118
	4 000: Blacks (OD ED EC DD) and LIDTs
Number of elements (total)	4 000; Blocks (OB, FB, FC, DB) and UDTs
DB • Number range	1 60 000; subdivided into: number range that can be used by the
Number range	1 60 999; subdivided into: number range that can be used by the user: 1 59 999, and number range of DBs created via SFC 86: 60 000 60 999
• Size, max.	1 Mbyte; For DBs with absolute addressing, the max. size is 64 KB
FB	
Number range	0 65 535
• Size, max.	200 kbyte
FC	
Number range	0 65 535
• Size, max.	200 kbyte
ОВ	
• Size, max.	200 kbyte
<ul> <li>Number of free cycle OBs</li> </ul>	100
Number of time alarm OBs	20
<ul> <li>Number of delay alarm OBs</li> </ul>	20
Number of cyclic interrupt OBs	20; With minimum OB 3x cycle of 500 µs
Number of process alarm OBs	50
Number of DPV1 alarm OBs	3
Number of isochronous mode OBs	1
Number of technology synchronous alarm OBs	2
Number of startup OBs	100
Number of startup OBs     Number of asynchronous error OBs	4
Number of asynchronous error OBs	2
Number of synchronous error OBs     Number of diagnostic alarm OBs	1
	1
Nesting depth	24: Unito 9 pagaible for Elblacks
• per priority class	24; Up to 8 possible for F-blocks
Counters, timers and their retentivity	
S7 counter	
Number	2 048
Retentivity	
— adjustable	Yes
IEC counter	
Number	Any (only limited by the main memory)
Retentivity	
— adjustable	Yes
S7 times	
Number	2 048
Retentivity	
— adjustable	Yes
IEC timer	
Number	Any (only limited by the main memory)
Retentivity	
— adjustable	Yes
Data areas and their retentivity	
Retentive data area (incl. timers, counters, flags), max.	128 kbyte; Available retentive memory for bit memories, timers, counters, DBs, and technology data (axes): 88 KB
Flag	
• Size, max.	16 kbyte
Number of clock memories	8; 8 clock memory bit, grouped into one clock memory byte
Data blocks	

Retentivity adjustable	Yes
Retentivity adjustable     Retentivity preset	No
Local data	NO
per priority class, max.	64 kbyte; max. 16 KB per block
Address area	OF ROYLO, HILLS. TO THE PER BIOCK
Number of IO modules	2 048; max. number of modules / submodules
I/O address area	2 046, max. number of modules / submodules
• Inputs	32 kbyte; All inputs are in the process image
Outputs	32 kbyte; All outputs are in the process image
per integrated IO subsystem	52 kbyte, All outputs are in the process image
— Inputs (volume)	8 kbyte
Outputs (volume)	8 kbyte
per CM/CP	o hoyte
— Inputs (volume)	8 kbyte
— Outputs (volume)	8 kbyte
Subprocess images	o hoyte
Number of subprocess images, max.	32
Address space per module	32
Address space per module, max.	288 byte; For input and output data respectively
Address space per module, max.  Address space per station	200 byte, 1 or impat and output data respectively
Address space per station, max.	2 560 byte; for central inputs and outputs; depending on configuration; 2
Address space per station, max.	048 bytes for ET 200SP modules + 512 bytes for ET 200AL modules
Hardware configuration	
Number of distributed IO systems	32; A distributed I/O system is characterized not only by the integration of distributed I/O via PROFINET or PROFIBUS communication modules, but also by the connection of I/O via AS-i master modules or links (e.g. IE/PB-Link)
Number of DP masters	
● Via CM	1
Number of IO Controllers	
• integrated	1
• Via CM	0
Rack	
Modules per rack, max.	80; CPU + 64 modules + server module (mounting width max. 1 m) + 16 ET 200AL modules
<ul> <li>Quantity of operable ET 200SP modules, max.</li> </ul>	64
<ul> <li>Quantity of operable ET 200AL modules, max.</li> </ul>	16
<ul> <li>Number of lines, max.</li> </ul>	1
PtP CM	
Number of PtP CMs	the number of connectable PtP CMs is only limited by the number of available slots
Time of day	
Clock	
• Type	Hardware clock
Backup time	6 wk; At 40 °C ambient temperature, typically
<ul> <li>Deviation per day, max.</li> </ul>	10 s; Typ.: 2 s
Operating hours counter	
Number	16
Clock synchronization	
• supported	Yes
• to DP, master	Yes; Via CM DP module
• to DP, slave	Yes; Via CM DP module
• in AS, master	Yes
• in AS, slave	Yes
<ul> <li>on Ethernet via NTP</li> </ul>	Yes
Interfaces	
Number of PROFINET interfaces	1
Number of PROFIBUS interfaces	1; Via CM DP module
Optical interface	Yes; via BusAdapter
1. Interface	
Interface types	

<ul><li>RJ 45 (Ethernet)</li></ul>	Yes; X1 P3; opt. X1 P1 and X1 P2 via BusAdapter BA 2x RJ45
<ul> <li>Number of ports</li> </ul>	3; 1. integr. + 2. via BusAdapter
<ul><li>integrated switch</li></ul>	Yes
BusAdapter (PROFINET)	Yes; compatible BusAdapters: BA 2x RJ45, BA 2x FC, BA 2x M12
Protocols	
IP protocol	Yes; IPv4
<ul> <li>PROFINET IO Controller</li> </ul>	Yes
<ul> <li>PROFINET IO Device</li> </ul>	Yes
<ul> <li>SIMATIC communication</li> </ul>	Yes
Open IE communication	Yes; Optionally also encrypted
Web server	Yes
Media redundancy	Yes; MRP Automanager according to IEC 62439-2 Edition 2.0
PROFINET IO Controller	
Services	
— PG/OP communication	Yes
<ul> <li>Isochronous mode</li> </ul>	Yes
<ul> <li>Direct data exchange</li> </ul>	Yes; Requirement: IRT and isochronous mode (MRPD optional)
— IRT	Yes
— PROFlenergy	Yes; per user program
<ul><li>— Prioritized startup</li></ul>	Yes; Max. 32 PROFINET devices
<ul> <li>Number of connectable IO Devices, max.</li> </ul>	128; In total, up to 512 distributed I/O devices can be connected via AS-i, PROFIBUS or PROFINET
<ul><li>Of which IO devices with IRT, max.</li></ul>	64
<ul> <li>Number of connectable IO Devices for RT,</li> </ul>	128
max.	400
— of which in line, max.	128
<ul> <li>Number of IO Devices that can be simultaneously activated/deactivated, max.</li> </ul>	8; in total across all interfaces
Number of IO Devices per tool, max.	8
Updating times	The minimum value of the update time also depends on communication
	share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data
Update time for IRT	
<ul><li>for send cycle of 250 μs</li></ul>	250 µs to 4 ms; Note: In the case of IRT with isochronous mode, the
	minimum update time of 500 μs of the isochronous OB is decisive
— for send cycle of 500 μs	500 μs to 8 ms
— for send cycle of 1 ms	1 ms to 16 ms
— tor send cycle at 2 ms	2 ms to 32 ms
— for send cycle of 2 ms	
— for send cycle of 4 ms	4 ms to 64 ms
<ul><li>for send cycle of 4 ms</li><li>With IRT and parameterization of "odd" send</li></ul>	4 ms to 64 ms Update time = set "odd" send clock (any multiple of 125 $\mu$ s: 375 $\mu$ s, 625
<ul> <li>for send cycle of 4 ms</li> <li>With IRT and parameterization of "odd" send cycles</li> </ul>	4 ms to 64 ms
for send cycle of 4 ms     With IRT and parameterization of "odd" send cycles  Update time for RT	4 ms to 64 ms Update time = set "odd" send clock (any multiple of 125 $\mu s$ : 375 $\mu s$ , 625 $\mu s$ 3 875 $\mu s$ )
<ul> <li>for send cycle of 4 ms</li> <li>With IRT and parameterization of "odd" send cycles</li> <li>Update time for RT</li> <li>for send cycle of 250 μs</li> </ul>	4 ms to 64 ms Update time = set "odd" send clock (any multiple of 125 $\mu$ s: 375 $\mu$ s, 625 $\mu$ s 3 875 $\mu$ s)
<ul> <li>for send cycle of 4 ms</li> <li>With IRT and parameterization of "odd" send cycles</li> <li>Update time for RT</li> <li>for send cycle of 250 μs</li> <li>for send cycle of 500 μs</li> </ul>	4 ms to 64 ms Update time = set "odd" send clock (any multiple of 125 $\mu$ s: 375 $\mu$ s, 625 $\mu$ s 3 875 $\mu$ s)
<ul> <li>for send cycle of 4 ms</li> <li>With IRT and parameterization of "odd" send cycles</li> <li>Update time for RT</li> <li>for send cycle of 250 μs</li> <li>for send cycle of 500 μs</li> <li>for send cycle of 1 ms</li> </ul>	4 ms to 64 ms Update time = set "odd" send clock (any multiple of 125 $\mu$ s: 375 $\mu$ s, 625 $\mu$ s 3 875 $\mu$ s) 250 $\mu$ s to 128 ms 500 $\mu$ s to 256 ms 1 ms to 512 ms
<ul> <li>for send cycle of 4 ms</li> <li>With IRT and parameterization of "odd" send cycles</li> <li>Update time for RT</li> <li>for send cycle of 250 μs</li> <li>for send cycle of 500 μs</li> <li>for send cycle of 1 ms</li> <li>for send cycle of 2 ms</li> </ul>	4 ms to 64 ms Update time = set "odd" send clock (any multiple of 125 $\mu$ s: 375 $\mu$ s, 625 $\mu$ s 3 875 $\mu$ s) 250 $\mu$ s to 128 ms 500 $\mu$ s to 256 ms 1 ms to 512 ms 2 ms to 512 ms
<ul> <li>for send cycle of 4 ms</li> <li>With IRT and parameterization of "odd" send cycles</li> <li>Update time for RT</li> <li>for send cycle of 250 μs</li> <li>for send cycle of 500 μs</li> <li>for send cycle of 1 ms</li> <li>for send cycle of 2 ms</li> <li>for send cycle of 4 ms</li> </ul>	4 ms to 64 ms Update time = set "odd" send clock (any multiple of 125 $\mu$ s: 375 $\mu$ s, 625 $\mu$ s 3 875 $\mu$ s) 250 $\mu$ s to 128 ms 500 $\mu$ s to 256 ms 1 ms to 512 ms
<ul> <li>for send cycle of 4 ms</li> <li>With IRT and parameterization of "odd" send cycles</li> <li>Update time for RT</li> <li>for send cycle of 250 μs</li> <li>for send cycle of 500 μs</li> <li>for send cycle of 1 ms</li> <li>for send cycle of 2 ms</li> </ul>	4 ms to 64 ms Update time = set "odd" send clock (any multiple of 125 $\mu$ s: 375 $\mu$ s, 625 $\mu$ s 3 875 $\mu$ s) 250 $\mu$ s to 128 ms 500 $\mu$ s to 256 ms 1 ms to 512 ms 2 ms to 512 ms
<ul> <li>for send cycle of 4 ms</li> <li>With IRT and parameterization of "odd" send cycles</li> <li>Update time for RT</li> <li>for send cycle of 250 μs</li> <li>for send cycle of 500 μs</li> <li>for send cycle of 1 ms</li> <li>for send cycle of 2 ms</li> <li>for send cycle of 4 ms</li> </ul> PROFINET IO Device Services	4 ms to 64 ms Update time = set "odd" send clock (any multiple of 125 $\mu$ s: 375 $\mu$ s, 625 $\mu$ s 3 875 $\mu$ s) 250 $\mu$ s to 128 ms 500 $\mu$ s to 256 ms 1 ms to 512 ms 2 ms to 512 ms
<ul> <li>for send cycle of 4 ms</li> <li>With IRT and parameterization of "odd" send cycles</li> <li>Update time for RT</li> <li>for send cycle of 250 μs</li> <li>for send cycle of 500 μs</li> <li>for send cycle of 1 ms</li> <li>for send cycle of 2 ms</li> <li>for send cycle of 4 ms</li> </ul> PROFINET IO Device Services <ul> <li>PG/OP communication</li> </ul>	4 ms to 64 ms Update time = set "odd" send clock (any multiple of 125 μs: 375 μs, 625 μs 3 875 μs)  250 μs to 128 ms 500 μs to 256 ms 1 ms to 512 ms 2 ms to 512 ms 4 ms to 512 ms
<ul> <li>for send cycle of 4 ms</li> <li>With IRT and parameterization of "odd" send cycles</li> <li>Update time for RT</li> <li>for send cycle of 250 μs</li> <li>for send cycle of 500 μs</li> <li>for send cycle of 1 ms</li> <li>for send cycle of 2 ms</li> <li>for send cycle of 4 ms</li> <li>PROFINET IO Device</li> <li>Services</li> <li>PG/OP communication</li> <li>Isochronous mode</li> </ul>	4 ms to 64 ms Update time = set "odd" send clock (any multiple of 125 μs: 375 μs, 625 μs 3 875 μs)  250 μs to 128 ms 500 μs to 256 ms 1 ms to 512 ms 2 ms to 512 ms 4 ms to 512 ms  Yes No
<ul> <li>for send cycle of 4 ms</li> <li>With IRT and parameterization of "odd" send cycles</li> <li>Update time for RT</li> <li>for send cycle of 250 μs</li> <li>for send cycle of 500 μs</li> <li>for send cycle of 1 ms</li> <li>for send cycle of 2 ms</li> <li>for send cycle of 4 ms</li> <li>PROFINET IO Device</li> <li>Services</li> <li>PG/OP communication</li> <li>Isochronous mode</li> <li>IRT</li> </ul>	4 ms to 64 ms Update time = set "odd" send clock (any multiple of 125 μs: 375 μs, 625 μs 3 875 μs)  250 μs to 128 ms 500 μs to 256 ms 1 ms to 512 ms 2 ms to 512 ms 4 ms to 512 ms  Yes No Yes
— for send cycle of 4 ms  — With IRT and parameterization of "odd" send cycles  Update time for RT  — for send cycle of 250 μs  — for send cycle of 500 μs  — for send cycle of 1 ms  — for send cycle of 2 ms  — for send cycle of 4 ms  PROFINET IO Device  Services  — PG/OP communication  — Isochronous mode  — IRT  — PROFIenergy	4 ms to 64 ms Update time = set "odd" send clock (any multiple of 125 μs: 375 μs, 625 μs 3 875 μs)  250 μs to 128 ms 500 μs to 256 ms 1 ms to 512 ms 2 ms to 512 ms 4 ms to 512 ms  Yes No Yes Yes; per user program
<ul> <li>for send cycle of 4 ms</li> <li>With IRT and parameterization of "odd" send cycles</li> <li>Update time for RT</li> <li>for send cycle of 250 μs</li> <li>for send cycle of 500 μs</li> <li>for send cycle of 1 ms</li> <li>for send cycle of 2 ms</li> <li>for send cycle of 4 ms</li> <li>PROFINET IO Device</li> <li>Services</li> <li>PG/OP communication</li> <li>Isochronous mode</li> <li>IRT</li> <li>PROFlenergy</li> <li>Shared device</li> </ul>	4 ms to 64 ms Update time = set "odd" send clock (any multiple of 125 μs: 375 μs, 625 μs 3 875 μs)  250 μs to 128 ms 500 μs to 256 ms 1 ms to 512 ms 2 ms to 512 ms 4 ms to 512 ms  Yes No Yes Yes; per user program Yes
— for send cycle of 4 ms  — With IRT and parameterization of "odd" send cycles  Update time for RT  — for send cycle of 250 μs  — for send cycle of 500 μs  — for send cycle of 1 ms  — for send cycle of 2 ms  — for send cycle of 4 ms  PROFINET IO Device  Services  — PG/OP communication  — Isochronous mode  — IRT  — PROFIenergy	4 ms to 64 ms Update time = set "odd" send clock (any multiple of 125 μs: 375 μs, 625 μs 3 875 μs)  250 μs to 128 ms 500 μs to 256 ms 1 ms to 512 ms 2 ms to 512 ms 4 ms to 512 ms  Yes No Yes Yes; per user program
<ul> <li>for send cycle of 4 ms</li> <li>With IRT and parameterization of "odd" send cycles</li> <li>Update time for RT</li> <li>for send cycle of 250 μs</li> <li>for send cycle of 500 μs</li> <li>for send cycle of 1 ms</li> <li>for send cycle of 2 ms</li> <li>for send cycle of 4 ms</li> <li>PROFINET IO Device</li> <li>Services</li> <li>PG/OP communication</li> <li>Isochronous mode</li> <li>IRT</li> <li>PROFlenergy</li> <li>Shared device</li> <li>Number of IO Controllers with shared device,</li> </ul>	4 ms to 64 ms Update time = set "odd" send clock (any multiple of 125 μs: 375 μs, 625 μs 3 875 μs)  250 μs to 128 ms 500 μs to 256 ms 1 ms to 512 ms 2 ms to 512 ms 4 ms to 512 ms  Yes No Yes Yes; per user program Yes
<ul> <li>for send cycle of 4 ms</li> <li>With IRT and parameterization of "odd" send cycles</li> <li>Update time for RT</li> <li>for send cycle of 250 μs</li> <li>for send cycle of 500 μs</li> <li>for send cycle of 1 ms</li> <li>for send cycle of 2 ms</li> <li>for send cycle of 4 ms</li> <li>PROFINET IO Device</li> <li>Services</li> <li>PG/OP communication</li> <li>Isochronous mode</li> <li>IRT</li> <li>PROFlenergy</li> <li>Shared device</li> <li>Number of IO Controllers with shared device, max.</li> </ul>	4 ms to 64 ms Update time = set "odd" send clock (any multiple of 125 μs: 375 μs, 625 μs 3 875 μs)  250 μs to 128 ms 500 μs to 256 ms 1 ms to 512 ms 2 ms to 512 ms 4 ms to 512 ms  Yes No Yes Yes; per user program Yes 4
<ul> <li>for send cycle of 4 ms</li> <li>With IRT and parameterization of "odd" send cycles</li> <li>Update time for RT</li> <li>for send cycle of 250 μs</li> <li>for send cycle of 500 μs</li> <li>for send cycle of 1 ms</li> <li>for send cycle of 2 ms</li> <li>for send cycle of 4 ms</li> <li>PROFINET IO Device</li> <li>Services</li> <li>PG/OP communication</li> <li>Isochronous mode</li> <li>IRT</li> <li>PROFlenergy</li> <li>Shared device</li> <li>Number of IO Controllers with shared device, max.</li> <li>activation/deactivation of I-devices</li> </ul>	4 ms to 64 ms Update time = set "odd" send clock (any multiple of 125 μs: 375 μs, 625 μs 3 875 μs)  250 μs to 128 ms 500 μs to 256 ms 1 ms to 512 ms 2 ms to 512 ms 4 ms to 512 ms  Yes No Yes Yes; per user program Yes 4 Yes; per user program
<ul> <li>for send cycle of 4 ms</li> <li>With IRT and parameterization of "odd" send cycles</li> <li>Update time for RT</li> <li>for send cycle of 250 μs</li> <li>for send cycle of 500 μs</li> <li>for send cycle of 1 ms</li> <li>for send cycle of 2 ms</li> <li>for send cycle of 4 ms</li> <li>PROFINET IO Device</li> <li>Services</li> <li>PG/OP communication</li> <li>Isochronous mode</li> <li>IRT</li> <li>PROFlenergy</li> <li>Shared device</li> <li>Number of IO Controllers with shared device, max.</li> <li>activation/deactivation of I-devices</li> <li>Asset management record</li> </ul>	4 ms to 64 ms Update time = set "odd" send clock (any multiple of 125 μs: 375 μs, 625 μs 3 875 μs)  250 μs to 128 ms 500 μs to 256 ms 1 ms to 512 ms 2 ms to 512 ms 4 ms to 512 ms  Yes No Yes Yes; per user program Yes 4 Yes; per user program
<ul> <li>for send cycle of 4 ms</li> <li>With IRT and parameterization of "odd" send cycles</li> <li>Update time for RT</li> <li>for send cycle of 250 μs</li> <li>for send cycle of 500 μs</li> <li>for send cycle of 1 ms</li> <li>for send cycle of 2 ms</li> <li>for send cycle of 4 ms</li> <li>PROFINET IO Device</li> <li>Services</li> <li>PG/OP communication</li> <li>Isochronous mode</li> <li>IRT</li> <li>PROFlenergy</li> <li>Shared device</li> <li>Number of IO Controllers with shared device, max.</li> <li>activation/deactivation of I-devices</li> <li>Asset management record</li> <li>Interface</li> </ul>	4 ms to 64 ms Update time = set "odd" send clock (any multiple of 125 μs: 375 μs, 625 μs 3 875 μs)  250 μs to 128 ms 500 μs to 256 ms 1 ms to 512 ms 2 ms to 512 ms 4 ms to 512 ms  Yes No Yes Yes; per user program Yes 4 Yes; per user program
<ul> <li>for send cycle of 4 ms</li> <li>With IRT and parameterization of "odd" send cycles</li> <li>Update time for RT</li> <li>for send cycle of 250 μs</li> <li>for send cycle of 500 μs</li> <li>for send cycle of 1 ms</li> <li>for send cycle of 2 ms</li> <li>for send cycle of 4 ms</li> <li>PROFINET IO Device</li> <li>Services</li> <li>PG/OP communication</li> <li>Isochronous mode</li> <li>IRT</li> <li>PROFlenergy</li> <li>Shared device</li> <li>Number of IO Controllers with shared device, max.</li> <li>activation/deactivation of I-devices</li> <li>Asset management record</li> <li>Interface</li> <li>Interface types</li> </ul>	4 ms to 64 ms Update time = set "odd" send clock (any multiple of 125 μs: 375 μs, 625 μs 3 875 μs)  250 μs to 128 ms 500 μs to 256 ms 1 ms to 512 ms 2 ms to 512 ms 4 ms to 512 ms  Yes No Yes Yes; per user program Yes 4  Yes; per user program Yes; per user program Yes; per user program

Protocols	
<ul> <li>PROFIBUS DP master</li> </ul>	Yes
<ul> <li>PROFIBUS DP slave</li> </ul>	Yes
SIMATIC communication	Yes
PROFIBUS DP master	
Number of connections, max.	48; Of which 4 each reserved for ES and HMI
Number of DP slaves, max.	125; In total, up to 512 distributed I/O devices can be connected via AS-
Transor of Briolavos, max.	i, PROFIBUS or PROFINET
Services	
— PG/OP communication	Yes
— Equidistance	No
— Isochronous mode	No
Activation/deactivation of DP slaves	Yes
Interface types	100
RJ 45 (Ethernet)	V.
• 100 Mbps	Yes
<ul> <li>Autonegotiation</li> </ul>	Yes
<ul> <li>Autocrossing</li> </ul>	Yes
Industrial Ethernet status LED	Yes
RS 485	
Transmission rate, max.	12 Mbit/s
Protocols	
PROFIsafe	Yes; V2.4 / V2.6
Number of connections	
Number of connections, max.	128; via integrated interfaces of the CPU and connected CPs / CMs
Number of connections reserved for ES/HMI/web	10
<ul> <li>Number of connections via integrated interfaces</li> </ul>	88
Number of connections per CP/CM	32
Number of S7 routing paths	16
Redundancy mode	10
H-Sync forwarding	Yes
	Tes
Media redundancy	V
— Media redundancy	Yes; only via BusAdapter
— MRP	Yes; MRP Automanager according to IEC 62439-2 Edition 2.0, MRP Manager; MRP Client
<ul> <li>MRP interconnection, supported</li> </ul>	Yes; as MRP ring node according to IEC 62439-2 Edition 3.0
— MRPD	Yes; Requirement: IRT
— Switchover time on line break, typ.	200 ms; For MRP, bumpless for MRPD
— Number of stations in the ring, max.	50
SIMATIC communication	W. T. O. W. T. O. W. C.
PG/OP communication	Yes; encryption with TLS V1.3 pre-selected
• S7 routing	Yes
<ul> <li>Data record routing</li> </ul>	Yes
<ul> <li>S7 communication, as server</li> </ul>	Yes
<ul> <li>S7 communication, as client</li> </ul>	Yes
User data per job, max.	See online help (S7 communication, user data size)
Open IE communication	
• TCP/IP	Yes
— Data length, max.	64 kbyte
<ul> <li>several passive connections per port, supported</li> </ul>	Yes
• ISO-on-TCP (RFC1006)	Yes
— Data length, max.	64 kbyte
• UDP	Yes
— Data length, max.	2 kbyte; 1 472 bytes for UDP broadcast
— UDP multicast	Yes; Max. 5 multicast circuits
DHCP	Yes
• DNS	Yes
• SNMP	Yes
• DCP	Yes
• LLDP	Yes

Encryption	Yes; Optional
Web server	
• HTTP	Yes; Standard and user pages
• HTTPS	Yes; Standard and user pages
OPC UA	
Runtime license required	Yes
OPC UA Client	Yes
<ul> <li>Application authentication</li> </ul>	Yes
— Security policies	Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256
<ul> <li>User authentication</li> </ul>	"anonymous" or by user name & password
<ul> <li>Number of connections, max.</li> </ul>	4
<ul> <li>Number of nodes of the client interfaces, max.</li> </ul>	1 000
<ul> <li>Number of elements for one call of OPC_UA_NodeGetHandleList/OPC_UA_ReadList/C max.</li> </ul>	300
<ul> <li>Number of elements for one call of OPC_UA_NameSpaceGetIndexList, max.</li> </ul>	20
<ul> <li>Number of elements for one call of OPC_UA_MethodGetHandleList, max.</li> </ul>	100
<ul> <li>Number of simultaneous calls of the client instructions per connection (except OPC_UA_ReadList,OPC_UA_WriteList,OPC_UA_M max.</li> </ul>	1
<ul> <li>Number of simultaneous calls of the client instructions</li> <li>OPC_UA_ReadList,OPC_UA_WriteList and OPC_UA_MethodCall, max.</li> </ul>	5
Number of registerable nodes, max.	5 000
Number of registerable modes, max.      Number of registerable method calls of	100
OPC_UA_MethodCall, max.	
Number of inputs/outputs when calling OPC_UA_MethodCall, max.  OPC_UA_Server.	20
OPC UA Server      — Application authentication	Yes; Data access (read, write, subscribe), method call, custom address space Yes
Security policies	Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256
— User authentication	"anonymous" or by user name & password
Number of sessions, max.	32
Number of accessible variables, max.	50 000
·	
Number of registerable nodes, max.	10 000
Number of subscriptions per session, max.	20
— Sampling interval, min.	100 ms
— Publishing interval, min.	500 ms
Number of server methods, max.	20
Number of inputs/outputs per server method, max.	20
Number of monitored items, max.	1 000; for 1 s sampling interval and 1 s send interval
Number of server interfaces, max.	10 of each "Server interfaces" / "Companion specification" type and 20 of the type "Reference namespace"
Number of nodes for user-defined server interfaces, max.	1 000
Further protocols	Vest MODRILIC TOR
MODBUS	Yes; MODBUS TCP
7 message functions	
Number of login stations for message functions, max.	32
Program alarms	Yes
Number of configurable program messages, max.	5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH
Number of loadable program messages in RUN, max.	2 500
est commissioning functions	
Joint commission (Team Engineering)	Yes; Parallel online access possible for up to 5 engineering systems
Status block	Yes; Up to 8 simultaneously (in total across all ES clients)

Single sten	No
Single step  Number of breakpoints	NO 8
Number of breakpoints Status/control	0
Status/control variable	Yes; without fail-safe
Variables	Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters
<ul><li>Number of variables, max.</li></ul>	inputs/outputs, memory bits, DBs, distributed 1/Os, timers, counters
of which status variables, max.	200; per job
of which states variables, max.  — of which control variables, max.	200; per job
Forcing	200, pci jub
• Forcing	Yes; without fail-safe
• Forcing, variables	Peripheral inputs/outputs
Number of variables, max.	200
Diagnostic buffer	
• present	Yes
Number of entries, max.	1 000
— of which powerfail-proof	500
Traces	
Number of configurable Traces	4; Up to 512 KB of data per trace are possible
Interrupts/diagnostics/status information	
Diagnostics indication LED	
• RUN/STOP LED	Yes
• ERROR LED	Yes
MAINT LED	Yes
<ul> <li>Monitoring of the supply voltage (PWR-LED)</li> </ul>	Yes
Connection display LINK TX/RX	Yes
Supported technology objects	
Motion Control	Yes; Note: The number of technology objects affects the cycle time of
	the PLC program; selection guide via the TIA Selection Tool
<ul> <li>Number of available Motion Control resources for technology objects</li> </ul>	800
<ul> <li>Required Motion Control resources</li> </ul>	
<ul><li>per speed-controlled axis</li></ul>	40
— per positioning axis	80
— per synchronous axis	160
— per external encoder	80
— per output cam	20
— per cam track	160
— per probe	40
Positioning axis     Number of positioning axes at motion control      (typical yellus)	5
cycle of 4 ms (typical value)	10
— Number of positioning axes at motion control cycle of 8 ms (typical value)  Controller	10
Controller	Voc. Universal PID controller with integrated antimination
PID_Compact     PID_3Stop	Yes; Universal PID controller with integrated optimization
PID_3Step     PID Town	Yes; PID controller with integrated optimization for valves
PID-Temp  Counting and measuring	Yes; PID controller with integrated optimization for temperature
Counting and measuring	Yes
High-speed counter  Standards approvals contificates	162
Standards, approvals, certificates  Highest safety class achievable in safety mode	
<ul> <li>Performance level according to ISO 13849-1</li> </ul>	PLe
SIL acc. to IEC 61508	SIL 3
Probability of failure (for service life of 20 years and repair	r time of 100 hours)
<ul> <li>Low demand mode: PFDavg in accordance with SIL3</li> </ul>	< 2.00E-05
High demand/continuous mode: PFH in accordance with SIL3	< 1.00E-09
Ambient conditions	
Ambient temperature during operation	
<ul> <li>horizontal installation, min.</li> </ul>	-25 °C; No condensation

<ul> <li>horizontal installation, max.</li> </ul>	60 °C
<ul> <li>vertical installation, min.</li> </ul>	-25 °C; No condensation
vertical installation, max.	50 °C
Altitude during operation relating to sea level	
<ul> <li>Installation altitude above sea level, max.</li> </ul>	5 000 m; Restrictions for installation altitudes > 2 000 m, see manual
configuration / header	
configuration / programming / header	
Programming language	
— LAD	Yes; incl. failsafe
— FBD	Yes; incl. failsafe
— STL	Yes
— SCL	Yes
— GRAPH	Yes
Know-how protection	
<ul> <li>User program protection/password protection</li> </ul>	Yes
<ul> <li>Copy protection</li> </ul>	Yes
<ul> <li>Block protection</li> </ul>	Yes
Access protection	
<ul> <li>protection of confidential configuration data</li> </ul>	Yes
<ul> <li>Protection level: Write protection</li> </ul>	Yes
<ul> <li>Protection level: Read/write protection</li> </ul>	Yes
<ul> <li>Protection level: Write protection for Failsafe</li> </ul>	Yes
<ul> <li>Protection level: Complete protection</li> </ul>	Yes
programming / cycle time monitoring / header	
<ul> <li>lower limit</li> </ul>	adjustable minimum cycle time
• upper limit	adjustable maximum cycle time
Dimensions	
Width	100 mm
Height	117 mm
Depth	75 mm
Weights	
Weight, approx.	310 g
last modified:	11/3/2021 🖸